



AJMER VIDYUT VITRAN NIGAM LIMITED

(Commercial Deptt.)

Corporate Identification Number (CIN)-U40109RJ2000SGC016482
Regd. Off Vidyut Bhawan, Panchsheel Nagar, Makarwali Road, Ajmer-305004
Phone No. 0145-2644501, Fax-2644502 E-Mail:- cecomavvnl@gmail.com
Website-www.energy.rajasthan.gov.in/avvnl



NO. AVVNL/ACE (HQ)/SE(C)/ XEN-I /F. 105C/2020-21/D. 52

Dated 13/5/2020


The Secretary,
Rajasthan Electricity Regulatory Commission,
Vidyut Viniyamak Bhawan, Sahkar Marg,
Near State Motor Garage, Jaipur.

Sub: - Regarding submission of SAIFI & SAIDI information in SOP-4 and SOP-5 formats for the month of February-2020.

Sir,

In reference to implementation of BRAP (Business Reform Action Plan) of GoR, the SOP information in respect of SAIFI (SOP-4) and SAIDI (SOP-5) for the month of February-2020 is enclosed herewith for publishing / uploading on Hon'ble Commission's website.

Encl.:- As above.


(N. S. Sahwal)

Addl. Chief Engineer (HQ)

Copy to the following for information & needful action please.

1. The Electricity Ombudsman Rajasthan, Jaipur.
2. The Superintending Engineer (IT) AVVNL, Ajmer for uploading on Nigam website.

Encl.:- As above.


Addl. Chief Engineer (HQ)

Reliability Indices
System Average Interruption Frequency Index (SAIFI)

Name of Licensee:-Ajmer Discom

SOP-4
For the month February-2020

| S.No. | Name of Circle | Total number of consumers served (1) | Total number of sustained interruptions to consumers (2) | SAIFI = (2) / (1) (Number of interruptions/ consumer) | Target specified by the Commission |
|-------|----------------|--------------------------------------|--|--|------------------------------------|
| 1 | AJMER (ACC) | 365215 | 3131979 | 8.58 | |
| 2 | AJMER (ADC) | 268076 | 2415693 | 9.01 | |
| 3 | BHILWARA | 536117 | 3834180 | 7.15 | |
| 4 | CHITTORGARH | 353281 | 1160145 | 3.28 | |
| 5 | UDAIPUR | 651043 | 2015383 | 3.10 | |
| 6 | BANSWARA | 295492 | 1194568 | 4.04 | |
| 7 | NAGAUR | 631285 | 2418732 | 3.83 | |
| 8 | SIKAR | 629863 | 2423379 | 3.85 | |
| 9 | JHUNJHUNU | 509997 | 1751969 | 3.44 | |
| 10 | RAJASAMAND | 279048 | 1699198 | 6.09 | |
| 11 | DUNGARPUR | 312273 | 621635 | 1.99 | |
| 12 | PRATAPGARH | 185904 | 688758 | 3.70 | |
| | Total | 5017594 | 23355619 | 4.65 | |

Reliability Indices
System Average Interruption Duration Index (SAIDI)

Name of Licensee:-Ajmer Discom

SOP-5
For the month February-2020

| S.No. | Name of Circle | Total number of consumers served (1) | Total minutes of sustained interruptions to consumers (2) | SAIDI = (2) / (1) (Minutes/ consumer) | Target specified by the Commission |
|-------|----------------|--------------------------------------|---|---------------------------------------|------------------------------------|
| 1 | AJMER (ACC) | 365215 | 34071137 | 93.29 | |
| 2 | AJMER (ADC) | 268076 | 29795535 | 111.15 | |
| 3 | BHILWARA | 536117 | 25612404 | 47.77 | |
| 4 | CHITTORGARH | 353281 | 17001205 | 48.12 | |
| 5 | UDAIPUR | 651043 | 12221727 | 18.77 | |
| 6 | BANSWARA | 295492 | 3487862 | 11.80 | |
| 7 | NAGAUR | 631285 | 15094342 | 23.91 | |
| 8 | SIKAR | 629863 | 44703357 | 70.97 | |
| 9 | JHUNJHUNU | 509997 | 11357996 | 22.27 | |
| 10 | RAJASAMAND | 279048 | 12545231 | 44.96 | |
| 11 | DUNGARPUR | 312273 | 4682322 | 14.99 | |
| 12 | PRATAPGARH | 185904 | 5603328 | 30.14 | |
| | Total | 5017594 | 216176446 | 43.08 | |