



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LTD.

(AN ISO 9001: 2008 CERTIFIED COMPANY)

OFFICE OF THE EXECUTIVE ENGINEER (220 KV GSS), KUKAS

Ph. No. 01426-227325; E - Mail: xen.220.kukas@rvpn.co.in

No. RVPN / XEN / 220 KV GSS / Kukas / Estt. / D. 574

Date: 24-01-2017

To

All registered contractors,

Under the jurisdiction of the ZCE (T&C), Jaipur.

Subject:- Consent for painting work of transformers/structures/Earthling/C&R Panels at 220 KV GSS, RVPN, Kukas (Jaipur) as per BSR for repair & maintenance work of EHV lines & GSS 2011.

With reference to above & being a registered contractor of Jaipur zone for work on CLRC. It is to inform you that this office proposed to award contract for painting work of transformers/structures etc at 220 KV GSS, Kukas as mentioned above is enclosed herewith for submitting your acceptance/willingness for carrying out the above work on rates including all taxes etc as per norms of RVPN CLRC rates & term & conditions issued vide order No.RVPN/SE/SSPC/TK/A.1/TN-1975/CLRC D.501 Dt. 24.05.2013. The financial implication of the proposed contract is Rs.238996 (Rs Two Lac thirty eight thousand nine hundred ninety six only) inclusive of 60% CLRC premium.

You are therefore requested to please submit your acceptance within 7 days in respect of above work on 31.01.2017 up to 03:00 PM positively.

(R. K. Meena)

Executive Engineer (220 KV GSS)
RVPNL, KUKAS

Copy submitted to The Superintending Engineer (T&C Rural), RVPN, Jaipur for kind information and n/a.

(R. K. Meena)


Executive Engineer (220 KV GSS)
RVPNL, KUKAS




RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LTD.
(AN ISO 9001: 2008 CERTIFIED COMPANY)
OFFICE OF THE EXECUTIVE ENGINEER (220 KV GSS), KUKAS Ph.
No. 01426-227325; E – Mail: xen.220.kukas@rvpn.co.in

S.NO	Description of Work	Area Sq Mtr	Rate as per BSR in Rs /Sq mtr	Total Amount
1	Aluminium Painting of old painted steel structure at the GSS including the supply of paint and painting brush, emery paper, cloth & solvents etc. The surface will be first cleaned with wire brush/emery paper and thereafter wiped with cloth to remove rust & dust or any other deposits on erected M S Steel structure and beams. One coat of red oxide paint shall be applied carrying out cleaning and allowed and dry. Thereafter, two coats of aluminium paint shall be applied, Each subsequent coat shall be applied only after the previous coat has dried up. The paint shall be used from any of the following recognized manufacturers namely Asian/Nerolac/Berger/Johnson Nicholson.	4749.14	24	113979.4
2	Enamel painting on M.S. flats and old painted M.K. at the GSS including paint and painting brush, emery paper, cloth & solvents etc. The surface shall be first cleaned with wire brush/emery paper and thereafter wiped with the clothes to remove rust and dust or any other deposit on erected flats and old painted M.K. One coat of red oxide paint shall be applied on M.S flats after carrying out cleaning allowed to dry.	523.73	25	13093.25
3	Enamel painting of Power Transformers & other associated equipments using sparay painting set including supply of paint, emery paper, clothes and solvents etc. at GSS by cleaning surfaces thoroughly with soda/caustic solution to clean oily surface & thereafter washing with water. There after two coats of smoke gray synthetic enamel paint shall be applied by spry method. Each coat shall be applied only after the previous coat has dried up. The paint used shall be out of the following recognized manufacturers only namely: Asian/Nerolac /Berger/Johnson Nicholson/Dulux. In case of surface area of radiators, the fins will only be considered which are only feasible & approachable for painting by spray spray or by Brush	892	25	22300

Total 149373
Add 60% Above as per BSR 89623.6
Total 238996
Round Off 238996


Assistant Engineer
220 KV GSS Kukas


Executive Engineer
220 KV GSS Kukas