



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
(An ISO 9001:2008 certified company)
OFFICE OF THE SUPERINTENDING ENGINEER (PROCUREMENT-I)
Gate #3, Old Power House Premises,
Near Ram Mandir, Banipark, JAIPUR- 302006
Phone: 0141-2208916 Fax: 0141-2208915

No. RVPN/SE/Proc-I/XEn-3/A-6/BN-9015001708/D. 1052


Dt. 05-X-2017

Amendment No.2
BID DOCUMENT NO. RVPN/SE/PROC-I/XEN-3/A-6/BN-9015001708

Following amendment in the Bid Document is hereby issued:

S. No.	Reference (Clause No./ Page No.)	Existing provision	Revised/ amended provision
1.	Clause 3.25 of Section -IIIA GENERAL REQUIREMENTS. Page 74	TRIPPING RELAY: High speed master tripping relay are required for Tripping. The relay should have 2 Normally Closed and 20 Normally Open hand reset pair of contacts for inter trip facility with duplicated trip contacts.	TRIPPING RELAY: High speed master tripping relay are required for Tripping. The relay should have 2 Normally Closed and 20 Normally Open electrically reset pair of contacts with push button for inter trip facility with duplicated trip contacts.

Other terms and conditions of the Bid Document shall remain unchanged.


(R.P. Gupta) 5/10
Superintending Engineer (Proc. -I)

