



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
(An ISO 9001:2008 certified company)
OFFICE OF THE SUPERINTENDING ENGINEER (PROCUREMENT-I)
Gate #3, Old Power House Premises,
Near Ram Mandir, Banipark, JAIPUR- 302006
Phone: 0141-2208916 Fax: 0141-2208915

No. RVPN/SE/Proc-I/XEn-3/A-6/BN-9015001708/D. 1111

Dt. 13-10-2017

Clarification
BID DOCUMENT NO. RVPN/SE/PROC-I/XEN-3/A-6/BN-9015001708


In light of Amendment no. 2 issued in Bid Document No. RVPN/ SE/ PROC-I/ XEN-3/ A-6/ BN-9015001708 vide No. RVPN/ SE/ Proc-I/ XEn-3/ A-6/ BN-9015001708/ D. 1052 Dt.5.10.2017 following clarifications are hereby issued:

1. Tripping relays for all duplex type C&R Panels (Type A-II, C-II, J-II, L-II, B-II, K-II & K-III) shall be electrical reset type with push button for manual trip facility irrespective of number of NO & NC contacts. Accordingly, following errata is issued:

S. No.	Reference	Existing provision	To be read as
1	Clause 3.25 of Section -IIIA GENERAL REQUIREMENTS. Page 74	TRIPPING RELAY: High speed master tripping relay are required for Tripping. The relay should have 2 Normally Closed and 20 Normally Open electrically reset pair of contacts with push button for inter trip facility with duplicated trip contacts.	TRIPPING RELAY: High speed master tripping relay are required for Tripping. The relay should have electrically reset pair of contacts with push button for inter trip facility with duplicated trip contacts.
2	Section -IIIJ Item 6 & 10 of Clause 12.04.2 Item 5 & 9 of Clause 12.05.2 Item 4 of Clause 12.06.2 Item 5 of Clause 12.07.2 Item 6 & 15 of Clause 12.08.2 Item 2 of Clause 12.09.2 Item 5 of Clause 12.10.2	... hand reset pair of contacts electrically reset pair of contacts with push button ...

2. Since LBB & Bus bar protection is not envisaged on 132 kV system, item 9 of clause 12.07.2, appearing due to typographical error, is deleted.

Other terms and conditions of the Bid Document shall remain unchanged.


(R.P. Gupta)
Superintending Engineer (Proc. -I)

