



JAIPUR VIDYUT VITRAN NIGAM LIMITED  
OFFICE OF THE SUPERINTENDING ENGINEER(I&S)  
OLD POWER HOUSE PREMISES, BANI PARK, JAIPUR-302 006  
TEL.:0141-2201582/FAX-0141-2201582/ email: seis@jvvn.in

Regd. Office: Vidyut Bhawan, Jyoti Nagar, Jaipur-302005, Tel.: 0141-2747017; Fax:-0141-2744187  
CIN: U40109RJ2000SGC016486 Website: [www.jaipurdiscom.com](http://www.jaipurdiscom.com)

No.JPD/SE(I&S)/D. 484

DATED: 16.6.2017

ORDER -42

Sub: Lifting of G.P. failed Distribution Transformers directly by the manufacturers from the circle stores and depositing the same at ACOS, Achrol Store after repair.

The manufacturer will lift the G.P. failed transformers directly from the concerned circle store **w.e.f. 01.07.2017** and may deposit the same after repair in the ACOS (JCC) at Achrol Store. The loading and un-loading of the G.P. failed transformers will be on the suppliers' account. However, one side transportation charges i.e. from ACOS (JCC) Achrol store to the circle store may be recovered from the firms as decided **by the Nigam**. The circle store will send the copy of intimation of failure also to the ACOS, JCC store while intimating to the firm and the supplier firm will also submit the joint inspection report along with the inspection report to the ACOS, JCC while depositing the G.P. repaired transformers along with the details of intimation of G.P. failed distribution transformers issued by the respective circle store for their record. The invoices of missing parts shall be verified as per Joint Inspection Report (in prescribed proforma) issued by the circle store as per practice invogue and accordingly the Sr. A.O. (CPC), JVVNL, Jaipur will make the payment of missing parts, if any. The ACOS, JCC will send the details of repair of each and every G.P. failed transformers rating-wise, TN-wise, Firm-wise mentioning the Sr. No. of the transformers, date of intimation and the date of receipt of the G.P. repaired transformers in ACOS, JCC store to the S.E. (MM) so that the penalty due to delay in G.P. repair may be finalized and SCBG of the firms may be released timely.

After expiry of guarantee period along with the G.P. repair period of one year, the tentative penalty due to delay in G.P. repair shall be finalized **considering max. 10% failure for three phase transformers** or as per actual failure intimated by the ACOS, JCC and **20% failure for Single Phase Transformers** or as per ACOS, JCC record whichever is more. However, final delay in G.P. repair shall be worked out on the basis of details of repair furnished by the ACOS, JCC store and the respective circle store where the firm's works is situated.

to Ref. M

The SCBG shall be released after depositing the aforesaid tentative recovery along with furnishing of an undertaking on a non-judicial stamp paper of Rs.100.00 that later if any left out transformer will found declared failed in guarantee period, the same shall also be repaired by the supplier free of cost.

The firm will repair and deposit G.P. failed distribution transformers within 120 days from the date of intimation of circle store failing which the full cost of the transformer shall be recovered without giving any further notice to the firm. The supplier shall furnish the copy of receipted challans of repaired transformers deposited at ACOS (JCC) Achrol store to the respective circle store from where G.P. failed transformers were lifted to make the entry in their (circle store) record that said transformer have been repaired and deposited by them. The circle store will send the list of suppliers alongwith quantity of G.P. failed distribution transformers firm-wise lying un-repaired beyond 120 days from the date of intimation either in store or at firms' works to the S.E. (MM), JVVNL, Jaipur to take further action for such distribution transformers.

*dm*  
16/6/17  
(R.K. MEENA)

SUPERINTENDING ENGINEER (I&S)

Copy to the following for information and necessary action.

1. The Chief Engineer (MM), JVVNL, Jaipur.
2. The Zonal Chief Engineer (J/Z, B/Z, K/Z), JVVNL, Jaipur/Bharatpur/Kota.
3. The Superintending Engineer (JCC/JPDC/O&M), Jaipur Discom, Jaipur/ Dausa/ Alwar/ Bharatpur/ Kota/ Sawaimadhopur/Jhalawar/Baran/Bundi/ Dholpur/ Karoli/Tonk. For strict compliance of the above order.
4. The Superintending Engineer (MM), JVVNL, Jaipur.
5. The T.A. to M.D./ Director (Tech.), JVVNL, Jaipur.
6. P.A. to Director (Finance), JVVNL, Jaipur.
7. ~~ACOS~~ ACOS (JCC/JPDC/O&M).

*dm*  
16/6/17  
SUPERINTENDING ENGINEER (I&S)

⑩ REF.