

JAIPUR VIDYUT VITRAN NIGAM LIMITED  
 OFFICE OF THE SUPERINTENDING ENGINEER (MM)  
 OLD POWER HOUSE, NEAR RAM MANDIR, BANI PARK, JAIPUR  
 PH: 2202607 FAX: 0141- 2202025

NO.JPD/SE/MM/SPO-VI/TN-2358/D. 2300

JAIPUR, DT. 15/09-2016

**ADDENDA**

Sub: Amendment in Technical Specification for supply of 3 KVAR L.T. Shunt Capacitors against TN-2358.

Following amendment in Technical Specification is hereby made to the extent as indicated below:

**Para No. 3 of Clause No. 14.3 of Specification and under the "Note" of Clause No. 3.01 "Type Test Criteria" of Pre-Qualification Requirement (Schedule-III-A) be amended as under:**

Price bids of the firms may be opened who have furnished the valid Type Test Reports which has been conducted at NABL Accredited Lab / Govt. approved Laboratory of offered type & design i.e. for 3 KVAR rating as per Clause No. 12.2.2 of IS:13340/1993 with latest amendments, if any, and not older than five years from the date of opening of Technical Bid.

**OR**

Price bids of the firms may be opened if the bidder furnishes an undertaking stating that valid type test certificate of offered type and design as per Clause No. 12.2.2 of IS:13340/1993 with latest amendments, if any from a Govt. / Govt. approved / Govt. recognized / NABL accredited / ILAC accredited laboratory **shall be furnished before commencement of supply or from first lot (without asking any delivery extension) along with the Type Test bank guarantee of Rs.5.0 lacs with the technical bid.**

**The date of opening of tender is hereby extended and now opened on dated 29.09.2016 in place of 22.09.2016.**

*Am*

**(ASHOK MATHUR)**  
 SUPERINTENDING ENGINEER (MM)

Copy to the Superintending Engineer (IT), JVVNL, Jaipur for information and uploading the same on the JVVNL Website.

*Ab*

**SUPERINTENDING ENGINEER (MM)**

*BH* *(w)*