



No.JdVVNL/MD/CE(HQ)/SE(RA&C)/JU/2020-21/D. 2388 Dt. 24.03.21

ORDER

Sub: Conductor for 11KV overhead lines.

Load of 11 KV and LT feeders is increasing day by day which needs augmentation of existing ACSR Weasel conductor to ACSR Rabbit conductor. Due to low mechanical strength of ACSR Weasel conductor, there is tendency of breaking of conductor thereby causing electrical accidents.

The matter was discussed in the Three Discoms Technical Specification Approval Committee meeting held on dated 09.11.2020 wherein it was decided that henceforth ACSR Rabbit conductor be used in place of ACSR Weasel conductor.

It is therefore, enjoined upon all the field officers to initially consume the available ACSR Weasel conductor for optimum utilization of available stock, thereafter ACSR Rabbit conductor be used in place of ACSR Weasel conductor.

By Order,


 24.3.21
 (A.K.MEENA)

**SUPERINTENDING ENGINEER (RA&C)
 JODHPUR DISCOM, JODHPUR**

Copy submitted/ forwarded to the following for information and necessary action:

- 1) The Director (Finance / Technical), Jodhpur Discom, Jodhpur.
- 2) The Zonal Chief Engineer (O&M-JDZ/ BMR/ BKZ), Jodhpur Discom, Jodhpur/ Barmer/Bikaner.
- 3) The Addl. Chief Engineer(S&T-CSS/ MM/IT&M&P), Jodhpur Discom, Jodhpur.
- 4) The Chief Accounts Officer(B&R/IA), Jodhpur Discom, Jodhpur.
- 5) The T.A. to Chairman, Discoms, Vidhyut Bhawan, Jaipur, for kind perusal of the Hon'ble Chairman.
- 6) The T.A. to Managing Director, Jodhpur Discom/Jaipur Discom/Ajmer Discom, Jodhpur /Jaipur/ Ajmer, for kind perusal of the Hon'ble MD.
- 7) The Company Secretary, Jodhpur Discom, Jodhpur.
- 8) The Superintending Engineer (CC / DC / O&M / BFL / PP&M / TW / M&P/ MM&C/ Vig.), Jodhpur Discom, Jodhpur / Pali / Barmer / Sirohi / Jalore / Jaisalmer / Bikaner / Hanumangarh / Sriganganagar / Churu/ Jaipur.
- 9) The Superintending Engineer(IT), Jodhpur Discom, Jodhpur for putting up the order on the website of Discom.
- 10) M/s Bikaner Electricity Supply Company, IInd Floor, 3-K-9, Pavanpuri, Bikaner(Raj). 334001 for circulating amongst officers under your control.
- 11) The P. S. to Hon'ble Energy Minister, Secretariat, GoR, Jaipur.
- 12) The P.S. to Secretary (Energy), Govt. of Rajasthan, Jaipur.
- 13) The TA to Electricity Ombudsman, Vidhyut Viniyamak Bhawan, Sahakar Marg, Near State Motor Garage, Jaipur, for kind perusal of Ombudsman.
- 14) The Addl. S. P. (Vigilance), Jodhpur Discom, Jodhpur. With spare copies for distribution amongst vigilance officers.
- 15) The Sr. Accounts Officer/Accounts Officer (O&M-CC / DC / Audit/ Rev), Jodhpur Discom, Jodhpur / Bikaner.
- 16) The Executive Engineer (O&M/ DD/ CTL/ A-B-C-Zone/ City-I-II/ Legal/ IA / Training/ Vigilance), Jodhpur Discom,..... **for circulating amongst all the AENs/JENS/ARO under your control.**
- 17) The Public Relation Officer, Jodhpur Discom, Jodhpur.
- 18)


 24.3.21
SUPERINTENDING ENGINEER (RA&C)
JODHPUR DISCOM, JODHPUR