

JODHPUR VIDYUT VITARAN NIGAM LIMITED

OFFICE OF THE SUPERINTENDING ENGINEER (MM)

NEW POWER HOUSE INDUSTRIAL AREA, JODHPUR

TELEPHONE: 0291-2742223 / FAX:- 0291-2746539

NO. JDVVNL/SE/MM&C/TN-1292/D.

3207

DATED

29 AUG 2017

CORRIGENDUM No. 1

TN-1292

(TENDER ENQUIRY FOR PURCHASE OF A.C. STATIC THREE PHASE, FOUR WIRE, HAVING DLMS PROTOCOL WITH OPTICAL & ADDITIONAL LPRF PORT 10-60A RATING WHOLE CURRENT, CLASS 1.0 ACCURACY, KWH ENERGY METERS HAVING POLYCARBONATE METER CASE AND BACKLIT LCD DISPLAY WITH SEPARATE MOULDED POLYCARBONATE CUPBOARD)

The Addendum/Corrigendum in the above technical specification is issued as under:-

Technical Specification (Section-III)

Following clauses are hereby amended to read as under:-

Sr. No.	Spec. Clause no.	Particulars	To be read as under:-
1.	16 (Samples)of Technical Spec. (Section - III - Volume- 'A')	<p>(a) Samples along with bid – The bidder shall furnish one meter and one meter Box conforming to this specification duly sealed along with routine test certificates in the office of SE (MM&C), JdVVNL, Jodhpur one day prior to the date of opening of Tender. If the samples are not received, the bid shall be considered as Non-responsive.</p> <p>(b) The sample meter along with meter box shall be checked / tested for mechanical/ physical features in Nigam's Lab. Sample meter shall be broken to verify components of the meter.</p> <p>(c) Bid stage samples shall be accepted in the office of SE (MM&C), JDVVNL, Jodhpur, by the committee of following officers.</p> <p>i. XEN (CTL), JDVVNL, Jodhpur.</p> <p>ii. XEN-TA to CE (MM), JDVVNL, Jodhpur.</p> <p>iii. XEN (MM-IV), JDVVNL, Jodhpur</p> <p>iv. AEN-VII (MM Division), JDVVNL, Jodhpur.</p> <p>The officers/committee which is authorised to accept the bid samples shall physically examine & match the details of sample items i.e. its make, SL. No., Seal no. etc. with the letter having the detail of the sample submitted by the bidder. RTC check shall also be performed on all sample meters while physically examining & accepting the bid stage samples. The received samples shall not be checked</p>	<p>This clause is hereby amended to read as:</p> <p>(a) Samples along with bid – The bidder shall furnish Eight meters and one meter Box conforming to this specification duly sealed along with routine test certificates in the office of SE (MM&C), JdVVNL, Jodhpur one day prior to the date of opening of Tender. If the samples are not received, the bid shall be considered as Non-responsive.</p> <p>Out of the above eight sample meters, six sample meters (one set of 3 samples for Electrical testing and another set of 3 samples for Environmental & Mechanical tests) and one sample shall be tested as per IS 15959 for one port (optical port) at CPRI, Bhopal/ Bangalore or ERDA, Vadodara in the presence of firm's representative. The testing charges shall be borne by the bidder. The tentative testing charges Rs. 6.5 lac shall be deposited by the bidder in the form of Demand Draft in favour of the Sr. Accounts Officer (Cash & CPC), Jodhpur Discom, Jodhpur.</p> <p>In case sample meters submitted by the bidder with bid don't conform the Type tests, Addl. Type Tests and Tamper tests of specification/ IS, the financial bid of that bidder shall not be opened.</p> <p>(b) One sample meter along with meter box shall be checked / tested for mechanical/ physical features in Nigam's Lab. Sample meter shall be broken to verify components of the meter.</p> <p>Note: - The bidders are required to furnish one no. CMRI and LPR Module along with communication cables so that the bid stage samples may be got checked/ verified.</p> <p>(c) Bid stage samples shall be accepted in the office of SE (MM&C), JDVVNL, Jodhpur, by the committee of following officers.</p> <p>i. XEN (CTL), JDVVNL, Jodhpur.</p> <p>ii. XEN-TA to CE (MM), JDVVNL, Jodhpur.</p> <p>iii. XEN (MM-IV), JDVVNL, Jodhpur</p>

