

**JODHPUR VIDYUT VITARAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (MM&C)**  
**NEW POWER HOUSE, INDUSTRIAL AREA, JODHPUR -342 003**

**Phone: (0291)2742223/Fax: (0291) 2746539/E-Mail-[semmcjdvvn@gmail.com](mailto:semmcjdvvn@gmail.com)**

**Corporate Identity Number (CIN)-U40109RJ2000SGC016483 GST No. 08AAACJ8578R1ZJ**

**SHORT TERM TENDER SPECIFICATION NO. JdVVNL/SE (MM&C)/EIAI/TN-1625**

**PURCHASE OF 11/√3 KV/240V, 5 KVA RATING OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE ALUMINIUM WOUND DISTRIBUTION TRANSFORMERS ENERGY EFFICIENCY LEVEL-2 WITH INBUILT CIRCUIT BREAKER UNDER SPECIFICATION NO. JdVVNL/SE (MM&C)/EIAI/TN-1625.**

Tenders are to be submitted online in electronic format on website <http://eproc.rajasthan.gov.in>. The details are as under-

S. N	ITEM	QUANTITY
1	11/√3 KV / 240 V, <b>5 KVA</b> ,OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE ALUMINIUM WOUND DISTRIBUTION TRANSFORMERS ENERGY EFFICIENCY LEVEL-2 WITH INBUILT CIRCUIT BREAKER	<b>11,280 Nos.</b>

A	NIT No.	<b>TN-1625</b>
B	Cost of tender specifications	Rs. 2500.00 + GST@18% = Rs. 2,950.00 (Rs. Two Thousand Nine Hundred & Fifty Only)
	Cost of tender specifications (For MSME UNITS)	Rs. 1250.00 + GST@18% = Rs. 1,475.00* (Rs. One Thousand Four Hundred & Seventy Five Only)
C	Processing fee of RISL	Rs. 1000.00 (One Thousand Only)
D	Estimated Tender Value	<b>Rs. 32,21,00,000.00</b>
E	Bid Security to be deposited with the tender	(i) General Bidder: Rs. 64,42,000.00 (ii) Sick Unit : Rs. 32,21,000.00 (iii) SSI Units of Rajasthan : Rs. 16,10,500.00*
F	Validity	120 days from the next date of opening of techno-commercial bid.
G	Base date for price variation	<b>The base date will be 01.06.2020 irrespective of date of tender opening.</b>

**IMPORTANT DATES**

S.N	Events	Date & Time	Location
1	Date of downloading of tender specifications	Up to 30.07.2020 (06:00 PM)	<a href="http://www.jdvvn.com">www.jdvvn.com</a> & <a href="http://eproc.rajasthan.gov.in">http://eproc.rajasthan.gov.in</a>
2	Deposit of cost of Tender Specifications, Processing fee & Bid Security.	Up to 30.07.2020 (4:00 PM)	Office of Sr. A.O (Cash & CPC), JdVVNL , New Power House, Industrial Area, Jodhpur
3	Last Date & time of submission of electronic bid	Up to 31.07.2020 (12:00 NOON)	<a href="http://eproc.rajasthan.gov.in">http://eproc.rajasthan.gov.in</a>
4	Opening of Technical Bid	31.07.2020 (3:00 PM)	<a href="http://eproc.rajasthan.gov.in">http://eproc.rajasthan.gov.in</a>
5	Opening of Price Bid	To be intimated separately to the qualified bidders	<a href="http://eproc.rajasthan.gov.in">http://eproc.rajasthan.gov.in</a>

**\*In case SSI unit of Rajasthan quotes the less than the tendered quantity , then they are required to furnish Bid security @ 0.5% of the estimated value of the quantity offered by them, failing which bid shall be considered non-responsive.**

The Micro, Small & Medium Scale Industries of Rajasthan and Sick Industries, other than Small Scale Industries, whose cases are pending before the Board of Industrial and Financial Reconstruction (BIFR) shall furnish self attested documentary evidence duly attested by notary to claim the above.

The bid security may be given in the form of banker's cheque or demand draft in favour of Senior Accounts Officer (Cash & CPC), JDVVNL, Jodhpur payable at Jodhpur or bank guarantee, in specified format, of a scheduled bank in favour of Superintending Engineer (MM&C), JDVVNL, Jodhpur, be deposited to the Sr. Accounts Officer (MM&C), JDVVNL, Jodhpur up to stipulated date & time, and obtain a receipt/acknowledgement thereof. No other mode of deposit shall be accepted.

**At the time of depositing the Bid security amount in the office of the Sr. Accounts Officer (MM&C), JDVVNL, Jodhpur, the bidder shall also furnish self-attested documentary evidence duly attested by Notary of SSI unit of Rajasthan and of sick unit and also to submit a letter of quantity offered by them alongwith an Affidavit for MSME unit of Rajasthan in the enclosed format as per Schedule XI is to be furnished on non-judicial stamp paper of Rs.100/- duly attested by Notary public, to the office of Sr. Accounts Officer (MM&C), JDVVNL, Jodhpur. The Bid Security bank guarantee of requisite amount shall be furnished on non-judicial stamp paper of Rajasthan State. Also furnish the undertaking for the CA certificate in the enclosed format as per Annexure-I on non-judicial stamp paper of Rs.100/- duly attested by Notary public alongwith the original / notarised CA certificate as per requirement of tender specifications.**

**NOTE:-**

- 1. Wherever EMD and Security Bank Guarantee (SBG), are appearing in the ITB, GCC & other Bidding Documents, same is hereby replaced by BID SECURITY as above.**
- 2. VENDOR REGISTRATION: The relaxation/exemption given to the registered vendors of the Nigam in respect of EMD/SBG, wherever appearing in the ITB, GCC & other Bidding documents, are hereby WITHDRAWN.**

**TENDER INDEX(TN-1625)**

Section-I	Instructions to bidders	<b>For e-Tendering</b>
Section-II	General Conditions of Contract	
Section-III	Technical Specification	
Schedule-I	Schedule of Requirement	
Schedule-II	Price Variation Formula	
Schedule-III	Details of Standards	
Schedule-III A	Pre Qualification Requirement (PQR)	
Schedule-III B	Performa for Bank Guarantee in lieu of Type Test	
Schedule-IV	Price Schedule(Bill of Quantity)	<b>To be uploaded on line on website in BOQ on website</b>
Schedule-IVA	Details of tendered quantity, quantity offered along with justification with reference to qualifying Requirement.	The bidder is required to justify quantity offered as per qualifying requirement.
Schedule V	Departure from Guaranteed Technical Particulars	
Schedule V (A)	Guaranteed Technical Particulars For Transformer.	
Schedule VI (A)	Departure from the requirement of Technical Specification.	
Schedule VI (B)	Departure from commercial terms & conditions of specification	
Schedule VII	List of Past Supplies	
Schedule VII A	C.A. Certificate for Quantity Justification.	
Schedule VIII	Delivery schedule.	
Schedule IX	List of equipment & technical hands available with the bidding firm.	
Schedule X	General Particulars about the bid in brief.	
Schedule XI	Format of Affidavit for Rajasthan MSME	
Annexure-A	Self Attested Undertaking To Be Given On Firm's Letter Head	
Annexure-I	Performa for Undertaking for CA certificate	
Appendix-A	Performa for Bank Guarantee in lieu of Bid Security	
General	Amendment in ITB and GCC	
	Addendum in ITB	

1. Tender documents will be made available on e-Tendering portal <http://www.eproc.rajasthan.gov.in/nicgep/app> . The bidders, in their own interest are requested to read very carefully the tender document before submitting the bid only through online on website <http://www.eproc.rajasthan.gov.in/nicgep/app>. The bidders can download bid upto 6.00 p.m. one day prior to schedule date of opening of respective bid mentioned above documents and submit their bids online upto 12.00 p.m. on schedule date of opening of respective bid mentioned above.
2. Eligible bidders should submit their bid well in advance instead of waiting till last date. JDVVNL will not be responsible for non-submission of Bid due to any website related problems.
3. The cost of Tender specification **Rs. 2,950/- (Non-Refundable)** to be paid by Demand Draft/Banker's Cheque in favour of the Sr. Accounts officer (Cash & CPC), JdVVNL, Jodhpur (payable at Jodhpur) and tender processing fees **Rs. 1000/- (Non- Refundable)** shall be payable by Demand Draft/Banker's Cheque in favour of The Managing Director RISL, Jaipur

(payable at Jaipur). The bidders are required to deposit all these payments in the office of the SE(MM&C), JdVVNL, Jodhpur up to 4.00 PM one WORKING day prior to schedule date of opening of respective bid otherwise their bids are liable to be rejected. Further, as per notification SO 165 issued by Fin. Dept. dt. 19.11.2015 on reference to RTPP rules, " clause 8(A)" bidding document shall be provided to MSME at 50% of prescribed cost.

4. The Bid Security amount (as applicable) to be paid by Demand Draft/Banker's Cheque in favour of SR. AO (CASH & CPC), JDVVNL, Jodhpur (payable at Jodhpur) **upto 4.00 p.m. upto one WORKING day prior to schedule date of opening** of respective bid or Bank Guarantee, in specified format, of a scheduled bank in favour of The Superintending Engineer (MM&C), JDVVNL, Jodhpur, be deposited to the Sr. Accounts Officer (MM&C), JDVVNL, New Power House, Industrial Area, Jodhpur-342003 **upto 4.00 p.m. upto one WORKING day prior to schedule date of opening** of respective bid **and obtain a receipt / acknowledgement thereof. No other mode of deposit shall be accepted.**
5. **\*In case SSI unit of Rajasthan quotes the less than the tendered quantity , then they are required to furnish Bid security @ 0.5% of the estimated value of the quantity offered by them, failing which bid shall be considered non-responsive.**
6. **Further, while depositing the bid security in the office of the Sr. Accounts Officer (MM&C), JDVVNL, Jodhpur, the bidder shall also furnish self-attested documentary evidence duly attested by Notary of SSI unit of Rajasthan or of sick unit (as applicable) and also to submit a letter of quantity offered by them alongwith an Affidavit for MSME unit of Rajasthan in the enclosed format as per Schedule XI is to be furnished on non-judicial stamp paper of Rs.100/- duly attested by Notary public, to the office of Sr. Accounts Officer (MM&C), JDVVNL, Jodhpur. The Bid Security bank guarantee of requisite amount shall be furnished on non-judicial stamp paper of Rajasthan State. Also furnish the undertaking for the CA certificate in the enclosed format as per Annexure-I on non-judicial stamp paper of Rs.100/- duly attested by Notary public alongwith the original / notorised CA certificate as per requirement of tender specifications.**
7. The Bank Guarantee against Bid Security be issued by Nationalized / Scheduled Bank. The same may be accepted after confirmation by issuing Bank. If any Bid Security Bank Guarantee not is proper format / not confirmed by the issuing Bank the same would not be accepted and the bidder would be immediately shorted out from bid process.
8. The bidders are required to **upload the** receipt of deposing all above payments along with their tender at the relevant place on the scheduled date & time otherwise their bids are liable to be rejected.

- Note :-**
1. All eligible interested bidders are required to get enrolled on e-Tendering portal <http://www.eproc.rajasthan.gov.in/nicgep/app>.
  2. If any difficulty arises, in down downloading/ uploading of tender you may contact in the RISL, Jaipur Rajasthan at following Contact/address.

**Address of RISL: -**

Raj COMP Info Services Limited (RISL)  
 1<sup>st</sup> Floor, Yojana Bhawan, Tilak Marg, C-Scheme, Jaipur  
 (Rajasthan)  
 Phone: 0141- 5103902, 4031900 Fax: 0141-2228701  
 Web: <http://risl.rajasthan.gov.in>  
 Email: [info.risi@rajasthan.gov.in](mailto:info.risi@rajasthan.gov.in)

**SECTION-III**

**JODHPUR VIDYUT VITARAN NIGAM LIMITED**

**TECHNICAL SPECIFICATION**

**FOR**

**11/√ 3KV/240 V, 5 KVA RATING OUTDOOR TYPE**

**COMPLETELY SELF PROTECTED SINGLE PHASE**

**ALUMINIUM WOUND**

**ENERGY EFFICIENT LEVEL-2**

**DISTRIBUTION TRANSFORMERS (WITH CRGO/ AMORPHOUS METAL CORE)  
WITH INTERNAL CIRCUIT BREAKER**

**AGAINST TN-1625**

**TECHNICAL SPECIFICATION FOR SUPPLY OF 11/ $\sqrt{3}$  KV / 240 V, 5 KVA RATING OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE ALUMINIUM WOUND ENERGY EFFICIENT LEVEL-2 DISTRIBUTION TRANSFORMERS WITH INBUILT CIRCUIT BREAKER AGAINST TN-1625.**

**1) SCOPE:**

This specification covers design, engineering, manufacture, assembly, stage testing, inspection & testing before supply and delivery at Nigam store(s) anywhere in Rajasthan of the oil immersed, oil natural air natural (ONAN) out door type 11kV /  $\sqrt{3}$  / 240 V, 50 Hz, 5 KVA Single Phase EEL-2 with **Aluminium wound** complete with fittings and accessories with meter protection unit on LT side of distribution transformers for use in distribution systems.

- 1.1 The Equipment Offered shall be complete with all parts necessary for their effective and trouble free operation. Such parts will be deemed to be within the scope of the supply irrespective of whether they are specifically indicated in the commercial order or not.
  - 1.1.1 It is not the intent to specify herein complete details of design and construction. The equipment offered shall conform to the relevant standards and be of high quality, sturdy, robust and of good design and workmanship complete in all respects and capable to perform continuous and satisfactory operations in the actual service conditions at site and shall have sufficiently long life in service as per statutory requirements. The dimensional drawings attached with this specification and the notes thereto are generally of illustrative nature. In actual practice, notwithstanding any anomalies, discrepancies, omissions, incompleteness, etc. in these specifications and attached drawings, the design and constructional aspects, including materials and dimensions, will be subject to good engineering practice in conformity with the required quality of the product, and to such tolerances, allowances and requirements for clearances etc. as are necessary by virtue of various stipulation in that respect in the relevant Indian Standards, IEC standards, I.E. Rules, I.E Act and other statutory provisions.
- 1.2 The Tender / supplier shall bind himself to abide by these considerations to the entire satisfaction of the Purchaser and will be required to adjust such details at no extra cost to the purchaser over and above the tendered rates and prices.
- 1.3 Tolerances on all the dimensions shall be in accordance with provisions made in the relevant Indian/ IEC standards and in these specifications. Otherwise the same will be governed by good engineering practice in conformity with required quality of the product.

2) **APPLICABLE STANDARDS:**

The materials shall conform in all respects to the relevant Indian Standard Specifications with latest amendments thereof; some of them are listed below:

Note: Wherever ISS are mentioned, equivalent or better International standards are also acceptable.

IS: 1180 (PART-I)/2014: Specifications for outdoor type oil immersed distribution transformers upto and including 2500 KVA, 33 KV Class.

IS/IEC 60947-2:2003 - low voltage switchgear and control gear – Part 2: Circuit Breaker.

IS:9385 Part-II:1980 – High voltage fuses : Part 2: Expulsion and similar fuses.

IS:8603:2008 – Dimensions for porcelain transformers bushings for use in heavily polluted atmospheres 12/17.5 kV, 24 kV and 36kV (Amalgamating IS 8603 (Parts 1,2&3) : 1977.

IS: 5/1961: Colour for ready mixed paints

IS:2026 (PARTI,II,III,IV & V)/1981 – Power Transformers.

IS:6600/1978 : Guide for loading of oil immersed Transformers

IS:335/1983 : New insulation oils for Transformers.

IS:3347 (PartI/Sec. 1 & 2): Dimension of Porcelain parts & Metal parts for Transformer bushing (1.1 KV)

IS:7421 : Porcelain Transformer Bushings for low voltage – upto 1 KV.

IS:2099/1986 : Porcelain Transformer bushing for AC volts above 1000 volts.

IS:3639/1966 : Fittings & accessories for Transformers.

IS:1866/1978:Code of practice for maintenance & supervision of insulating oil in Service.

IS:9335 : Specifications for insulating kraft paper.

IS:1576 : Specifications for solid insulating press Boards for electrical purposes.

IS:104 : Ready mixed paint, brushing zinc chromate, painting.

IS:649 : Testing of steel sheets and strips for magnetic circuits.

IS:2362 : Determination of water content in oil for porcelain bushing transformers.

IS: 4257: Dimensions for clamping arrangements for bushings.

IS 6160 : Rectangular conductor for electrical machines.

IS:10028 : Selection, Installation and maintenance of transformers.

IS: 5484: Specifications for Aluminium wire rods.

REC Specification No. 2.

REC Specification No. 39/1993.

CEA Specification, Chapter 4.

IEC: 994: Specification Part4 for Surge Arresters without gap for AC system.

IS: 3070 (PartIII): Specification for Lightning Arresters for alternating current System Part.III.

IS: 3073/1974 : Specification for Lightning Arresters.

IS: 2629: Recommended practice for hot dip galvanizing of iron and steel.

IS: 2633: Method for testing uniformity of coating on Zinc coated articles.

IS: 5621: Specification for large hollow porcelain for use in electrical installation.

IS: 13947 (PartII) latest : Specification for Single Pole MCCB.

IS: 2147: Degree of protection provided by enclosures for low voltage switchgear and control gear.

IEC Pub 609472: Specification for Low Voltage Switch Gear and Control gear.

Material conforming to other internationally accepted standards, which ensure equal or higher quality than the standards mentioned above would also be acceptable. In case the Bidders who wish to offer material conforming to the other standards, salient points of difference between the standards adopted and the specific standards shall be clearly brought out in relevant schedule. Four copies of such standards with authentic English Translations shall be furnished along with the offer.

**Note:- Besides above changes, the technical parameters of the specifications wherever are deviating from the IS:1180 (Part-I/2014) , the same shall be in accordance with IS:1180 (Part-I/2014) and its latest amendments, if any and the changes where the IS:1180 (Part-I/2014) is silent for technical parameters, same shall be applicable as per Discom specification.**

### **3) SERVICE CONDITIONS:**

The distribution transformers to be supplied against this specification shall be suitable for satisfactory continuous operation under the following climatic conditions as per IS 2026 (Part I) latest revision.

- |     |                                      |   |       |
|-----|--------------------------------------|---|-------|
| i)  | Peak ambient temperature             | : | 50°C. |
| ii) | Minimum Ambient Temperature in shade | : | 5°C.  |



- iii) Maximum average ambient temp in 24 hours period in shade : 45°C
- iv) Maximum yearly weighted average ambient temperature : 35°C
- v) Maximum temperature attainable by an object exposed to sun : 60°C
- vi) Maximum relative humidity : 100%
- vii) Average number of thunder storm days per annum : 40
- viii) Average number of rainy days per annum : 120
- ix) Average annual rainfall : 15-100 cm
- x) Number of months of tropical monsoon conditions : 4 Months
- xi) Maximum wind pressure : 195 kg/mt<sup>2</sup>
- xii) Altitudes :Not exceeding 1000 mtrs

The equipment shall be for use in moderately hot and humid tropical climate, conducive to rust and fungus growth.

#### 4. **PRINCIPAL PARAMETERS:**

The single phase transformers of standard ratings 5 KVA shall be suitable for outdoor installation with Single Phase, 50 Hz, 11KV system in which the neutral is effectively earthed and should be suitable for outdoor service under fluctuations in supply voltage upto plus 10% to minus 15%.

The transformer shall conform to the following specific parameters.

S.N	Particulars	Parameters
1	Continuous rated capacity	5 KVA
2	System voltage ( max.)	12KV
3	Rated voltage HV	11/ $\sqrt{3}$ KV
4	Rated voltage LV	240 V
5	Line current HV	0.79 A
6	Line current LV	20.83 A
7	Frequency	50 c/s +/- 3%
8	No. of phases	Single
9	Vector Group	IiO
10	Type of transformer	Outdoor
11	Type of cooling	ONAN
12	Class of insulation	Class A
13	Winding Material	Aluminium
14	Material of core	CRGO/AMORPHOUS
15	Type of core construction	Wound
16	Over fluxing limit (due to combined effect of voltage and frequency )	12.5 %
17	Permissible temperature over ambient under full load condition: i)Of top oil measured by thermometer ii) Of winding measured by resistance	35 Deg.C 40 Deg.C

18	Minimum clearances in air a) Phase to earth (mm) H.T b) Phase to earth (mm) LT	140 40
19	Total losses (watts) at 75 Deg. C. (Max.) (As per Energy Efficient level-2) i)At 50% loading ii)At 100% loading	<b>35 watts</b> <b>95 watts</b>
20	% age Impedance (with a tolerance of $\pm 10\%$ )	<b>2.5 % (<math>\pm 10\%</math> Tolerance)</b>
21	Max. Flux Density at Normal voltage and frequency	1.6 Tesla
22	Max. Current density	1.6 A/mm Sq
23	LT Breaker	Internally mounted
24	Radiator required	Not required
25	Magnetizing Current (max.) a) At 100% rated voltage  b) At 112.5% rated voltage	2%+30% tolerance on 2% as per IS:2026 of rated full load current  4% + 30% tolerance on 4% as per IS:2026 of rated full load current.

**ELECTRICAL CLEARANCES:**

- a) Minimum External Clearances (in air as per IS:1180)
- |                            |     |
|----------------------------|-----|
| i) HV phase to earth (mm)  | 140 |
| ii) LV phase to earth (mm) | 40  |
- b) Minimum Internal Clearances
- |   |    |    |
|---|----|----|
| i) Clearance between inner wall of tank and coil (mm) | -- | 12 |
| ii) Radial clearance between HV & LV windings (mm)    | -- | 3  |
| iii) Radial clearance of LV coil from core (mm)       | -- | 2  |
| iv) End clearance of HV coil from Yoke (mm)           | -- | 15 |
- V) Minimum Gap between core & tank bottom for oil circulation (mm)- 5**

**5) DESIGN & CONSTRUCTION:****5.1 Winding connection & terminal arrangements:**

For HV, live end should be brought out through 12kV bushing and the other end of HV, which is intended to be earth, shall be brought out on 1.1kV bushing (HV Neutral bushing). Provision shall be made for connecting the neutral HV terminal to local earth **through a strip having width of 25 mm and 1 mm thickness**. The secondary (LV) winding shall be connected to LV bushings. The 12 KV HV bushing (live) shall be provided on top cover and the remaining three bushing(s) shall be provided on the sidewall of the tank and below top cover.

Two layer of electrical grade insulation kraft paper (**epoxy dotted**) of 2 mil thickness or one layer of minimum 4 mil thickness shall be used for interlayer insulation both for HV and LV Coils.

**(A)The following method shall be adopted for taking out HV connections-**

a) Starting and finishing leads of HT coils shall be covered with empire sleeve(s) of proper size. These leads should be clamped with the body of the winding with the help of cotton twine during manufacture of the coils.

b) HT line leads shall be taken out through multiple paper covered (MPC) copper wires of sufficient cross section area to impart the desired mechanical strength. The current density in HV lead wire shall not exceed 0.8 A/mm<sup>2</sup>. These lead wires shall be provided with multi layer paper insulation of minimum 1.0 mm thickness i.e. minimum increase in diameter due to paper insulation shall not be less than 2 mm.

**(B)The following method shall be adopted for taking out LV connections**

a) The layers in LT Coil may be either even or odd in numbers but minimum layers shall be two.

b) LV Leads from winding shall be connected to the flat by brazing.

c) Firm connection of LT winding to bushing shall be made of adequate size of "L shape flat". Connection of LT coils to L shape flat shall be by brazing only.

d) "L" shape Flat shall be clamped to LV Bushing metal part(s) by using nut, lock nut and washer.

e) For Aluminium windings, L&T, ALKAPEE Aluminium brazing rods with suitable flux will be used.

**5.2 INSULATION MATERIALS:**

The following approved make of electrical grade insulation craft papers and boards shall be used in the transformer.

Sr. No.	Name of insulating material	Name of Firms
1.	Press board	(a) Senapathy whitely (b) Raman Board (c) Techno Electric, Hyderabad
2.	Kraft Paper	(a) Ballarpur (b) Padamjee (c) ITC Tribeni Tissue Paper Ltd., Kolkata (d) Munskjo, Sweden
3.	Press phan paper	Senapathy whitely
4.	Gaskets	(a) New cork (b) Talbros

**5.3 Bushings**

- i) The bushing shall conform to IS: 2099/3347 as amended upto date. Bushings having the creepage distance suitable for highly polluted atmosphere and having type tested as per IS: 3347 and IS:2099 latest version shall only be accepted.
- ii) For HV, 12kV class bushings and for earth/neutral of HV winding 1.1kV class bushing(s) shall be used and for LV, 1.1kV class bushing(s) shall be used.
- iii) The terminal arrangement shall not require a separate oil chamber.
- iv) The HV bushing shall be mounted on top cover and LV bushing(s) shall be mounted on side wall of tank below top cover. The bushing rods and nuts shall

be of brass.

- v) **The arcing horns for HV bushings shall be single gap and fixed type.**
- vi) HV bushing mounting bolt should be tag welded.

#### **5.4 CORE, WINDING AND OIL**

##### **5.4.1 CORE MATERIAL:**

###### a) **CRGO MATERIAL:**

Transformer core shall be wound core construction in shell type or core type, using prime grade imported M4 or better COLD ROLLED GRAIN ORIENTED (CRGO) laminations or any other combination of better grade be acceptable. The bidder shall furnish the core loss (watt per Kg.) and power (VA per Kg.) curves of the laminations used. The core shall be properly stress relieved by annealing in inert atmosphere. The transformer shall be suitable for over fluxing (due to combined effect of voltage and frequency) up to 12.5% without injurious heating. The operating flux density shall be such that there is a clear safe margin over the fluxing limit of 12.5%.

CRGO Laminations used shall be of prime grade and not second grade steel laminations. Only those bidders who directly imported CRGO either from the manufacturer or through their accredited marketing organization of repute (and not through any agent) shall be considered.

#### **ALTERNATIVE**

###### B) **AMORPHOUS METAL CORE**

The core shall be made of high quality Amorphous ribbons having very low loss formed into wound cores of rectangular shape, bolted together to the frames firmly to prevent vibration or noise. The complete design of core must ensure permanency of the core losses with continuous working of the transformers. The value of the maximum flux density allowed in the design shall be clearly stated in the offer. Curve showing the properties of the metal shall be attached with the offer. The transformer core shall be suitable for over fluxing (due to combined effect of voltage and frequency) upto 12.5% without injurious heating at full load conditions and shall not get saturated. The bidder shall furnish necessary data in support of this situation.

Core clamping for Amorphous metal transformers.

1. Core clamping shall be with top and bottom U-shaped core clamps made of sheet steel clamped with HT steel strap for efficient clamping.
2. MS core clamps shall be painted with varnish or oil-resistant paint.
3. Suitable provision shall be made in the bottom core clamp/bottom plate of the transformer to arrest movement of the active part.

**NOTE: Equal Weightage shall be given to the transformer with amorphous metal core and CRGO core.**

#### **5.4.2 FLUX DENSITY:**

Flux density should not be more than 1.6 Tesla(For 5 KVA) at the rated voltage and frequency. Transformer core should be designed in such a way that it will not get saturated for any value of V/f (Voltage/frequency) ratio to the extent of 112.5% of rated value of V/f ratio (i.e., 11000/50) and that the maximum flux density in any part of the core and yoke at rated voltage & frequency shall be such that the flux density with +12.5% combined voltage & frequency variations from rated voltage & frequency does not exceed 1.9 Tesla. (as per amended IS:1180 (Part-I/2014) Actual core design along with calculations in support of it should be enclosed with the offer.

#### **5.4.3 WINDING:**

HV and LV windings shall be wound from Aluminium conductors with DPC/Polyesterimide enamel (Class H) insulation. The enamel covering shall conform to Grade-II of IS:13730 Part8 or IEC 60317 Part8. The windings shall be progressively wound in LVHV coil design for better voltage regulation and mechanical strength. The inter layer insulation shall be of Epoxy resin bond paper. The type of winding i.e. whether LV windings are of conventional type or foil wound shall be indicated in the tender. Winding must be done in cleanest possible atmosphere to prevent possible accumulation of dust particles. The coil shall be further processed for dimensional control, improved bonding and for improving short circuit withstanding capability.

The current density of winding shall not be more than 1.6 Amp./sq.mm for Aluminium. The test reports for material characteristics like density, tensile strength and elongation, moisture content, ash content, dielectric strength, thickness of resin etc. for epoxy dotted paper shall be submitted during stage inspection.

#### **5.4.4 CORE COIL ASSEMBLY:**

Core coil assembly shall be further processed in oven for removal of moisture.

Ample provision for free circulation of oil in the radial gap between the core & LV Coil shall be made. The core shall be effectively earthed through **tinned copper foil of 25 mm width and 1 mm thickness** bolted on core clamps, after removing the core clamp paint.

**All core-coil assembly shall be punched on core channel / a identity plate welded on core channel with following details:**

1. Name of Supplier:
2. Order / TN No:
3. Rating:
4. Sr. No. of Transformer:

**In case if above marking is not found on the core assembly of physically opened transformer selected for physical verification during final inspection then no further inspection shall be carried out and re-inspection charges shall be payable by the supplier.**

#### 5.4.5 OIL:

The transformer shall be supplied complete with first filling of EHV Grade transformer oil, up to the normal oil level. The oil shall conform to IS: 335/1993 (latest amended) and should be ISI Marked and having the specified aging characteristics.

**The Break Down Voltage Value of the fresh oil after filtration and before filling in the transformer should be above 60 KV and after filling in the transformer it should be above 40 KV.**

The make of Transformer Oil shall be either APAR/SAVITA/ RAJ LUBRICANTS/ ANAMIKA/SHARAVATI/ MADRAS PETRO/ RAJ PETROL/ LUBRICHEM, MUMBAI/ OPANAMA PETROCHEM, ANKELSHWAR/ TASHKENT OIL, VADODARA/COLUMBIA. The transformer oil sample taken from the transformer shall be subject to testing as per provisions of IS:1866.

The oil manufacturer's test certificate shall be made available at the time of inspection to the inspecting officer.

#### 5.5 BUSHING TERMINALS:

##### 5.5.1 H.V. TERMINALS:

HV terminals shall be designed to directly receive ACSR conductor up to 7/3.35 mm (without requiring the use of the lug) **with the help of HV Bi-metallic connector.**

Starting and finishing leads of HT coils shall be covered with empire sleeve(s) or paper tube(s) of proper size. These leads should be clamped with the body of the winding with the help of cotton twine or permacel tape during manufacturing of the coils.

The transformer shall be provided with outdoor type 01 No. porcelain bushings, conforming to IS:3347/1972 & IS:2099/1973 from the manufacturer of repute. The HV bushings shall be on top of the tank and shall be fitted on a pocket made on top cover.. The bushings rods and nuts shall be made of brass. The inner porcelain portion of the bushing shall be projected about 50% of the length inside the bushing pocket. **HT bushing(s) mounting bolts should be tag welded.**

The clamping ring of HV bushing shall be of galvanised MS Sheet having minimum thickness of 1.6 mm. The total weight of all the 12 aluminium caste member of HV bushing shall not be less than 210 grams.

The arcing horn(s) shall be single gap and fixed type. HV bushings shall be of reputed make such as BEPCO, JAYSHREE, WSI, SESHASAYEE, JAIPUR GLASS, BPPL Bikaner, Agarwal salt Co. Bikaner, Baid Sanitary Works, Bikaner/ Krishna Ceramics, Nasirabad/ADPRO/SHINE or any other make - approved by the purchaser. The HV bushings shall generally conform to IS: 3347 and IS: 2099. Embossing showing the manufacturer's name and month & year of manufacture shall be clearly visible on HV bushings, even after fixing on transformer(s).

##### 5.5.2 L.T TERMINALS:

The LV coil shall be taken by cut on the top core clamp duly reinforced to compensate for the mechanical strength.

In case of internal L.T. Breaker, the L.T. bushing and the terminals shall be suitable for being concealed inside the distribution box having insulated aluminium bus bar of suitable size (as per the enclosed drawing) from where the connections shall be taken

for two or three numbers single core L.T. Aluminium Bunched Cable of size 16 sq.mm through cable glands for release of single phase connections to the consumer.

The LV bushings shall be of reputed make such as BEPCO, JAYSHREE, WSI, SESHASAYEE, JAIPUR GLASS, BPPL Bikaner, Agarwal salt Co. Bikaner, Baid Sanitary Works, Bikaner/ Krishna Ceramics, Nasirabad/ADPRO/SHINE or any other make - approved by the purchaser. The LV bushings shall generally conform to IS: 3347 and IS: 7421”.

## 5.6 **TANK:**

- a) The oil volume inside the tank shall be such that even under the extreme operating conditions, the pressure generated inside the tank does not exceed 0.4 kg/sq.cm positive or negative. There must be sufficient space from the core to the top cover to take care of oil expansion.
- b) The tank cover shall have plasticised surface on live parts to guard against bird faults. Alternately, suitable insulating shrouds shall be provided on the bushing terminals.
- c) **The Sheet thickness of transformer tank is as under:**
  - i) Main Tank : 2.0 mm (Min)
  - ii) Top Cover : 2.5 mm (min.)
  - iii) Bottom Cover : 2.5 mm (min.)

The tank without oil shall be capable of withstanding a pressure of 0.8 kg/cm<sup>2</sup> (g) above atmosphere at a vacuum of 760 mm of Hg for 30 minutes without any permanent deflection ( pressure test shall be conducted as per IS -1180 Part-I). The permanent deflection should not be more than the limits specified in IS:1180 Part-I.

## d) **MEASUREMENT OF SHEET THICKNESS OF TRANSFORMER TANK/ METER & PROTECTION BOX:**

The following measurements shall be carried out at respective Central Testing Lab (CTL) of the Discom(s) on the supplies of distribution transformers:

Measurement of Transformer Tank Thickness shall be done as follows:-

1.	Top Cover	At 2 places to be measured & average is to be taken.
2.	Bottom Cover	-do-
3.	Side Wall(s)	On all four sides (average is to be taken)
4.	M&P Box.	Both sides and front (average is to be taken)

- The nominal value of sheet thickness will be considered as mentioned in the Specification.
- Rolling tolerance will be as per ISS:1852-1985 with latest amendment and no penalty will be charged on such measured thickness till tolerance limit of ISS.
- Sheet thickness of transformer tank/ M&P Box for Distribution Transformers as per relevant tender specification are as under for ready reference:

Sr. No.	Rating	Top Cover (mm)	Bottom Cover (mm)	Side of Tank(mm)	M&P Box (mm)
1	5 KVA Single Phase	2.5	2.5	2.0	2.0

**The measurements of sheet thickness & size of Box will be carried out on all those sample transformers which are tested in CTL and test results will be applicable to the respective sub-lot or part thereof from which the sample is drawn.**

**NOTE\_ Firm may supply M.S. Sheet type OR Deep Drawn type Meter & Protection Boxes.**

**5.7** The following shall also be adhered:

- The long seam joint, CSEAM joint, fittings & accessories and other welds shall be oil tight and no deflection/ bulging should occur during service.
- Manufacturer should carry out the all welding operations as per relevant ASME standards and submit a copy of the welding procedure, qualifications and welder qualification certificate.
- The circular bottom plate edges of the tank should be folded upward, for at least 25mm to have sufficient over lap with vertical sidewall of the transformer.

Tank shall have permanent lugs for the lifting the Transformer body and there shall be facilities for lifting the core coil assembly separately.

The Transformer shall be provided with two mounting lugs suitable for fixing the transformer to a single pole by means of 2 bolts of 20 mm diameter as per ANSIC 57.12.201988. Both mounting lugs shall be made of steel of min. 6 mm thickness. Jump proof arrangements shall be provided on upper mounting lugs and lips shall be provided on lower mounting lugs for proper mounting of transformer on the pole. Both mounting lugs faces shall be in one plane.

The Transformer tank and the top cover shall be designed in such a manner as to leave no external pockets in which water can lodge. The top cover shall be fixed to the tank by proper arrangement to avoid ingress of moisture. Design of the top cover shall be such that no water can lodge on the top side. HV bushing pocket shall be embossed to top side of the top cover so as to eliminate ingress of moisture and water. The edges of the top cover shall be formed, so as to cover the top end of the tank and gasket.

**Oil level gauge of prismatic glass, indicating minimum position corresponds to operating temperature of 30 °C as per IS 1180 Part-1 : 2014 , shall be provided above the Internal circuit breaker height.** Nitrite/neoprene rubber gaskets conforming to latest IS:4253 Part-II shall be provided between tank and top cover.

Continuous welding of one inch length each should be provided at four places on ring (i.e. welding the clamping ring at top cover as well as with tank) and nut bolt of the ring should be tag welded.

On each transformer stainless steel anti theft fastener of suitable size shall be provided for clamping rim to hold fast tank and tank cover. In case of flange provided on top cover 2 Nos. stainless steel anti theft fastener shall be used and in case of rim type tank top cover 1 No. anti theft fastener shall be used. **Alternatively Dome shaped side clamping type construction of clamping bolts with stopper washer with tack welding for antitheft purpose for top cover.**

## **6) TANK SEALING:**

The space on the top of the oil shall be filled with dry air or nitrogen. The dry air (or nitrogen) plus oil volume inside the tank shall be such that even under extreme operating conditions, the pressure generated inside the tank does not exceed



0.4 kg/sq.cm positive or negative The nitrogen shall conform to commercial grade of relevant standards.

## **7) SURFACE PREPARATION & PAINTING :**

### **7.1 General:**

All paints shall be applied in accordance with the paint manufacturer's recommendations. Particular attention shall be paid to the following:

- a) Proper storage to avoid exposure as well as extreme of temperature.
- b) Surface preparation prior to painting.
- c) Mixing and thinning.
- d) Application of paints and the recommended limit on time intervals between coats.
- e) Shelf life for storage.

All paints, when applied in a normal full coat, shall be free from runs, sags, wrinkles, patchiness, brush marks or other defects.

All primers shall be well marked into the surface, particularly in areas where painting is evident and the first priming coat shall be applied as soon as possible after cleaning. The paint shall be applied by airless spray according to manufacturer's recommendations. However, wherever airless spray is not possible, conventional spray shall be used with prior approval of Purchaser.

The manufacturer shall, prior to painting protect nameplates, lettering gauges, sight glasses, light fittings and similar such items.

### **7.2 Cleaning and Surface Preparation:**

After all machining, forming and welding has been completed, all steel work surfaces shall be thoroughly cleaned of rust, scale, welding slag or spatter and other contamination prior to any painting.

Steel surfaces shall be prepared by SAND/SHOT blast cleaning to Grade Sa. 2.5 of ISO 85011 or Chemical cleaning by Seven Tank Process including Phosphating ( IS 3618).

The pressure and volume of the compressed air supply for blast cleaning shall meet the work requirements and shall be sufficiently free from all water contamination to ensure that the cleaning process is not impaired.

Chipping, scraping and steel wire brushing using manual or power driven tools cannot remove firmly adherent millscale and shall only be used where SAND/ shot blast cleaning is impractical. Manufacturer shall indicate such location, for owner's information, in his offer.

### **7.3 Protective Coating:**

As soon as all items have been cleaned and within four hours of the subsequent drying, they shall be given suitable anticorrosion protection.

#### **7.4 Paint Material:**

Following are the types of paint that may be used for the items to be painted at shop and supply of matching paint to site:

Heat resistant paint shall be (Hot oil Proof) for inside surface.

Inside of tank oil shall be painted with varnish or oil resistance paint. For external surface, one coat of thermo-setting powder paint or one coat of epoxy primer followed by 2 coat of polyurethane base paint shall be used .Total Dry film thickness as per IS 1180 Part-1 2014.

The colour of the finishing coats shall be olive green colour conforming to Shade No. 220 of IS -5 of 1961.

#### **7.5 Painting Procedure:**

All painting shall be carried out in conformity with both specification and with the paint manufacturer's recommendation. All paints in any one particular system, whether shop or site applied, shall originate from one paint manufacturer.

Particular attention shall be paid to the manufacturer's instructions on storage, mixing, thinning and pot life. The paint shall only be applied in the manner detailed by the manufacturer e.g. brush, roller, Conventional air spray and shall be applied under the manufacturer's recommended condition.

Minimum and maximum time intervals between coats shall be closely followed.

All prepared steel surfaces should be primed before visible rerusting occurs or within 4 hours, whichever is sooner. Chemical treated steel surfaces shall be primed as soon as the surface is dry and while the surface is still warm.

Where the quality of the film is impaired by excess film thickness (wrinkling, mud cracking or general softness) the supplier shall remove the unsatisfactory paint coating and apply another. As a general rule, dry film thickness should not exceed the specified minimum dry film thickness by more than 25%. In all instances where two or more coats of the same paint are specified, such coatings may or may not be of contrasting colours.

Paint applied to items that are not to be painted shall be removed at Supplier's expense, leaving the surface clean, unstained and undamaged.

#### **7.6 Damaged Paintwork:**

Any damage occurring to any part of a painting scheme shall be made good to the same standard of corrosion protection and appearance as that originally employed.

Any damaged paintwork shall be made good as follows:

- a) The damaged area, together with an area exceeding 25 mm around its boundary, shall be cleaned down to bare metal.
- b) A priming coat shall be immediately applied, followed by a full paint finish equal to that originally applied and exceeding 50 mm around the perimeter of the

- original damage.
- c) The repainted surface shall present a smooth surface. This shall be obtained by carefully chamfering the paint edges before and after printing.

### 7.7 Dry Film Thickness:

To the maximum extent practicable the coats shall be applied as a continuous film of uniform thickness and free of pores. Over spray, skips, runs, sags and drips should be avoided. The different coats may or may not be of the same colour.

Each coat of paint shall be allowed to harden before the next is applied as per manufacturer's recommendation.

The requirement for the dry type film thickness (DFT) of paint and the materials to be used shall be as given below.

Sl. No.	Paint Type	Area to be Painted	No. of coats	Total Dry film thickness (min.)
1.	Thermosetting Powder Paint	Inside Outside	01 01	30 microns 60 microns
2.	Liquid Paint a) Epoxy( Primer) b) Polyurethane base(Finish coat) c) Heat resistance paint (Hot oil proof Paint)	Outside Outside Inside	01 02 01	30 microns 25 microns each 35/10 microns

### 7.8 Tests:

The painted surface shall be tested for paint thickness.

The painted surface shall pass the Cross Hatch Adhesion Test.

## 8 RATING AND TERMINAL PLATES

- 8.1 **Rating & terminal marking plate:** Each Transformer shall be provided with non detachable name, rating and terminal marking plate fitted in a visible position. All details shall be given on one plate. Material of the plate shall be stainless steel/**Aluminium** only. Thickness shall be 0.9 mm (with a tolerance of  $\pm 0.1$  mm). The plate shall be made absolutely undetachable either through welding or riveting or through any other approved method.

There shall be a rating plate on the transformer containing the information given in the relevant ISS.

**Each HV , LV & Neutral terminal shall be duly indelibly marked with its terminal numbers with Min. letter size of 40X40 mm (e.g. HV phase terminal as 1.1 , HV neutral terminal as 1.2, LV phase terminal as 2.1 , LV neutral terminal as 2.2) by stamping.** In the diagram to be given on the name plate, the relative position of various terminals when viewed shall be clearly visible. Inspection shall not be undertaken unless all these details are verified by the Inspecting Officer.

- 8.2 Besides other particulars, following details shall also be given on the name

plate:

- i) P.O. No. month & year.
- ii) Sr. No. of transformer.
- iii) Date of despatch month & year.
- iv) Date of expiry of guarantee period – month & year.
- v) Maximum Guaranteed Load Losses at 50% and 100% loading.
- vi) Recommended fuse sizes for HV & LV sides.
- vii) Name & Full address of the manufacturer.
- viii) Capacity of the transformer.
- ix) Rating of the transformer.
- x) Type – Oil filled naturally cooled.
- xi) Energy Efficient level-2 and Standard IS1180 Part-1 with BIS Licence No.

ALL DETAILS ON THE “NAME RATING AND DIAGRAM PLATE” SHALL BE INDELIGIBLY MARKED i.e. BY ENGRAVING OR PUNCHING

**(A) Technical cum Identification Plate:** M.S. plate of size 125 x 75 x 2.5 mm having following details punched with letters of size 8mm x 6mm shall be continuously welded to the main tank body below the middle HV bushing and on Top Cover of tank in clearly visible position:-

- A) Name of the Firm
- B) TN No.
- C) Make
- D) Sr. No.
- E) Jodhpur Discom
- F) Rating
- G) Date of Dispatch
- H) Date of Expiry of G.P.
- I) Core : Core Dia. \_\_\_\_\_ And Core Area. \_\_\_\_\_
- J) LV Coil :-
  1. ID/OD Dimensions
  2. Conductor Size
- K) HV Coil :-
  1. ID/OD Dimensions
  2. Conductor Size
- L) Window Height

**B. Identification Mark:-** In addition to above, the following identifying details shall be clearly punched on the brackets which are attached to the transformer with minimum 10 mm x 10 mm x 1 mm size punch letters.

**MAKE** \_\_\_\_\_  
**S. No.** \_\_\_\_\_  
**T N** \_\_\_\_\_

The above identification mark shall also be punched / welded to one of the top core clamping channels.

## **9.0 PRESSURE RELEASE DEVICE:-**

The transformer shall be equipped with a selfsealing pressure release device designed to operate at a minimum pressure of 8 PSI (0.564 Kg/Cm<sup>2</sup>).

**10 FITTINGS:**

The following standard fittings shall be provided with each transformer.

- a) Two earthing terminals.
- b) Two lifting lugs.
- c) Rating and terminal marking plate shall be non-detachable and affixed with Min. 8 rivets (One each in centre of width and length side at equal distance and 4 Nos. each on corners), details to be included in one plate only. The plate shall be of stainless steel/Aluminium only, with details clearly marked. The base plate of the Rating and terminal marking plate shall be continuously welded with the tank

**Note:- Any one corner of the Rating and terminal marking plate is to be sealed by the inspecting officer.**

- d) Pressure relief device.
- e) Internal Circuit Breaker (On LV Side).
- f) HV Bushings.
- g) LV Bushings.
- h) HV terminal connectors.
- i) Top cover fixing clamps.
- j) Mounting lugs - 2 Nos.
- k) Bird guard or plasticised cover on live parts.
- l) LV earthing arrangement
- m) Operating Mechanism of of LT Circuit breaker.
- n) Signal Light.
- o) Guarantee period plate.
- p) Any other fitting necessary for satisfactory performance of the manufacturer as per IS:1180 Part-1(2014).
- q) Oil level gauge of prismatic glass
- r) Mounting Arrangement with pole will be as per drawing enclosed at Annexure-'B' for 5 KVA Single Phase Distribution Transformer. The mounting structure/ arrangement shall be in the scope of supplier.
- s) **QR Code:-QR code laminated P touch labels shall be fixed on transformer tank body below the name plate and on the core coil assembly (on core channel) depicting various technical details such as Name of manufacturer, rating, Serial no, TN No. etc. QR Code with desired information to be printed on non-tearable matt finish label and to be covered with transparent label to retain label life for minimum 20 years. Provision of Sr. No. on QR Code to be affixed on Core Coil assembly (on core channel) is optional.**

**11.0 FASTENERS**

- All bolts, studs, screw threads, pipe threads, bolt heads and nuts shall comply with the appropriate Indian Standards for metric threads, or the technical equivalent. Bolts or studs shall not be less than 6 mm in diameter except when used for small wiring terminals.
- All nuts and pins shall be adequately locked.
- **All Nuts, Bolts / Washers / Fasteners exposed to atmosphere used in transformers and Meter Protection Box should be of Stainless Steel.**
- Each bolt or stud shall project at least one thread but not more than three threads through the nut, except when otherwise approved for terminal board studs or relay stems If bolts are provided at inaccessible places

- for ordinary spanners, special spanners shall be provided.
- The length of screwed portion of the bolts shall be such that no screw thread may form part of a sheer plane between members.
  - Taper washers shall be provided where necessary. Protective washers of suitable material shall be provided front and back of the securing screws.

## 12.0 LOSSES:

The total losses at 50% and 100% loading for single phase **5 KVA** Transformers at rated voltage, frequency & 75 Deg. C shall not exceed the following values:

Rating in KVA	Voltage ratio in KV	Total losses at 50% loading (Watt) Max.	Total losses at 100% loading (Watt) Max.
5	$11/\sqrt{3}/0.240$	<b>35</b>	<b>95</b>

These losses are maximum allowable **as per Energy Efficient level-2**, and there would not be any positive tolerance. Transformer with higher losses than the above specified losses would be rejected.

## 13.0 IMPEDANCE:

The recommended percentage impedance at rated current and at 75 Deg. C **2.5** % (with a tolerance of  $\pm 10\%$ ).

## 14.0 TEMPERATURE RISE:

The temperature rise over ambient shall not exceed the limits described below:

Top oil temperature rise measured by thermometer	:	35 Deg.C
Winding temperature rise measured by method	:	40 Deg.C

**Temperature rise test shall be conducted on Maximum measured total loss (No load at rated excitation + Load loss at max. current tap at 75°C) at 100% loading shall be supplied during temperature rise test at a Govt. approved/ a Govt. recognized/ NABL accredited laboratory/ILAC i.e. International Laboratory Accredited Laboratory/ ILAC i.e. International Laboratory Accreditation Cooperation (in case of foreign laboratory).**

The limit of temperature rise mentioned above will have to be satisfied by the manufacturer by carrying the Heat Run Test by feeding guaranteed losses.

In case the temperature rise exceeds the above values, transformers shall be rejected at risk, cost and responsibility of the supplier.

It must be noted carefully that readings for hot resistance after shut down shall be taken separately for HV & LV windings, which means, after completing the readings for one winding (HV or LV), the transformer shall be connected again and rated current passed for another 60 minutes (min.) and shut down taken again to take hot resistance readings for the remaining winding. This is in line with the requirement of CBIP manual, to ensure proper resistance v/s time curves.

Hot Spot temperature not to exceed 98 Deg. C when calculated over an annual weighted average ambient temperature of 35 Deg. C as per IS:2026 (Part-II Clause 4.9.4) **However, the transformer shall be designed for class 'A' insulation.**

**The transformer shall be capable of giving continuous rated output without exceeding the specified temperature rise. Bids not conforming to the limits indicated above will be treated as non-responsive.**

## **15.0 GUARANTEED AND OTHER TECHNICAL PARTICULARS FOR TRANSFORMERS**

Guaranteed Technical particulars of the transformers offered shall be furnished in A-4 size paper by the Tenderer in the proforma appended herewith at **Annexure-A**. Complete details shall be furnished. Tolerances on weight quantity and dimension figures shall be  $\pm 2\%$  at the tender stage, subject to maintaining the minimum electrical clearances as per the specification. However, no negative tolerance shall be allowed on the short circuit type tested design. Electrical performance data shall be subject to tolerances as per ISS, unless otherwise specified in this specification. However, the Total losses at 50% & 100 % loading shall be maximum guaranteed without any positive tolerance.

## **16.0 TYPE TEST CERTIFICATE**

The bidder shall furnish type test certificate(s) of offered design / similar design, wherever available with the bid.

### **(i) DRAWING AND OTHER DOCUMENTS:**

One set of **3- dimensional drawing(s)** and internal construction drawing of each transformer rating shall be submitted with the tender. The tender shall be accompanied with the following drawings/calculation sheets, as per the offered designs. Size of the drawings shall be A3 (420 x 297 mm) or A4 size only.

- a) Name rating/diagram plate drawings.
- b) Outline and General arrangement drawings
- c) Core coil assembly drawings
- d) Core section along with flux density calculation sheet / drawings.
- e) Cooling area calculation sheet
- f) Thermal ability short circuit calculation sheet
- g) Core loss and magnetization curves of the laminations
- h) Heat dissipation calculations (heat dissipation by tank walls excluding top and bottom should be 500 W/ sq.mm.

Any delay in submission of drawings shall be to supplier's account.

**i) The Type test certificate of Internal circuit breaker conducted in the manufacturer which should be not older than 5 years from date of opening of the bid.**

## **17.0 PROTECTION:**

The transformer shall have the following CSP features for Internal Circuit Breaker:

The Meter Protection Box shall have one chamber only containing LT Bushing & outgoing LT terminal Bushings as per IS 3347 (Brass) for releasing consumer connections. The chamber is fully sealed. The drawing of the LT Box is enclosed at Annexure-A.

In 10% qty. of Meter Protection Box a provision for installation of Meter visible through glass window be kept in separate chamber for which the requirement shall be intimated as and when required during the execution of contract.

**Further Following provisions be also ensured on M&P Box and Transformer:-**

- i. On each transformers stainless steel anti theft fastener of suitable size shall be provided for clamping rim to hold fast tank and tank cover.
- ii. The M&P Box is firmly fixed with the transformer tank by providing all the nuts and bolts (total 8 Nos.) as per specification/approved drawing.
- iii. The Stainless Steel Anti-Theft Nuts and bolts should be provided on all the four corner bolts of box and remaining nuts should be tack welded with the bolts.
- iv. Hexagonal head of all the anti-theft nuts should be removed/detached so that the purpose of use of anti-theft nut and bolt be fulfilled.
- v. It should be ensured that there should be continuous welding on the complete M&P Box and in case if only tack welding is found on the M&P Box body then the complete lot may not be accepted.
- vi. M&P Box should be properly fixed with LT side flange of transformer by using min. 3 mm thick gasket so that water should not be go inside of M&P Box.  
(The above 5-Points appearing at Sr. No. 1 to 6 will be checked in Central Testing Lab)

### 17.1 The transformer shall have the following CSP features:

- (a) **INTERNAL HV FUSES ON THE HT SIDE OF TRANSFORMER as per IS9385 Part-II:1980**

Specification for the HT fuses: Expulsion / any other suitable fuse placed in series with primary winding. This fuse is mounted normally inside of the primary bushing and is connected to the high voltage winding through a terminal block. Fuse shall be mounted in such a way that it should be possible to replace the fuse by opening HV bushing and without opening top cover.

This has to protect that part of the electrical distribution system which is ahead of the Distribution transformers from faults which occur inside the Distribution transformers i.e., either the windings or some other part of the transformer. It shall be ensured that this fuse does not blow for faults on the secondary side (LT side) of the transformer i.e., the blowing characteristic of the fuse and LT breaker shall be so coordinated that the fuse shall not blow for any faults on the secondary side of the transformer and these faults shall be cleaned by the LT breaker only.

The fuse shall be make of ABB/ERMCO/Global/samrakshna/Transguard or any make approved by JDVVNL.

- (b) **INTERNALLY MOUNTED OIL IMMERSSED LT BREAKER ON THE LV SIDE OF THE TRANSFORMER as per IS/IEC 60947-2:2003:**

**LT circuit breaker:** All LT faults after the breaker shall be cleared by this breaker. As such, it shall be designed for the perfect coordination with the HT fuse link. The supplier shall furnish the time/current characteristics of LT circuit breaker and 11 kV fuses for various current multiples. The two characteristics shall be drawn on the same sheet to indicate coordination between the circuit breaker and fuse. This shall be based on the type test carried out on one of the transformers. In addition, the supplier shall carry out coordination test as indicated above, and this forms one of the test for acceptance.

The breaker is to be mounted on the secondary side of the transformer under oil to minimize premature operations from primary surges as would be with undersized line fuses. Two single pole elements is preferred. THE BREAKER SHALL BE COORDINATED TRHEMALLY WITH THE TRANSFORMER RATING TO FOLLOW CLOSELY THE VARIATIONS OF COIL TEMPERATURE DUE TO FLUCTUATIONS IN LOADS AND AMBIENT TEMPERATURES.

This is to be accomplished by connecting the breaker in series between the



secondary winding and the load current. The breaker shall be located in the same oil as the core and coil assembly so that the bimetal are sensitive to the temperature of oil as well as the load current.

**(c)**The circuit breaker may be an electromechanical device with three elements viz..

(i) Temperature sensing (ii) latching and tripping and (iii) current interrupting. The temperature sensing function might be accomplished through the use of bimetallic strips, which would be built into the breaker, such that load current of the transformer flows through them. In addition to this, a magnetic tripping device is to be provided for increasing the opening speed of the breaker under high fault conditions. The circuit breaker shall be mounted inside of the transformer so that these bimetallic strips are within the top oil layer of the transformer. The latching and tripping functions of the circuit breaker may be carried out within assembly similar to those used in industrial type air circuit breaker. The circuit breaker shall also be closed and opened manually standing on ground and with a magnetic trip device also. The current interruption element shall consist of copper current carrying parts plus a set of copper tungsten current interrupting contacts. The magnetic element shall increase the opening speed of the circuit breaker under high fault current conditions. The response of circuit breaker to the activity shall remain unchanged by the addition of the magnetic trip element. The specification to which the breakers conform shall be indicated. **The LT circuit breaker shall be made of samrakshna/Transguard/ Vijai Mercantile/ Global/ P&A/ ARDRY/ERMCO or any make approved by JDVVNL**

## **17.2 LOAD MANAGEMENT SIGNAL LIGHT:**

A signal light, controlled by a bimetal in the breaker shall switch on when the transformer load reaches a predetermined level indicating that the transformer has been overloaded. The load management signal light shall perform two functions. It shall show visually when the particular transformer has been operating in an overload condition and shall provide knowledge that for good system management, the economical change out point for the transformer is fast approaching. The signal light need not indicate temporary overloads and shall turn on only when the overload condition has existed at a given level for a certain length of time.

The LT circuit breaker shall have a set of auxiliary contacts built in for signal light operation. These, normally open contact, shall form part of the signal light circuit. The signal light circuit shall consist of an auxiliary transformer winding (one or two turns) which generates about 4V, for the signal light contact set within the circuit breaker, and the signal light is to be mounted on the transformer tank. The signal light contact set is mechanically connected to the main circuit breaker latching and bimetal system. The signal light mechanism is adjusted so that the signal light contacts will close at a preset thermal condition which occurs before the main latching system opens the main contact. The net result is a visual external indication that a preset load condition has reached by the transformer. The signal light mechanism does not reset itself when the load drops off, the signal light remains lighted once the signal light contacts closes and can only be turned off by manually operating the external circuit breaker handle.

**17.3 A distribution box is an enclosure (IP 33) is ready to be used condition and to be mounted on the transformer tank directly. The enclosure shall be made**

**with sheet of thickness not less than 2.0 mm.** It shall be painted with colour Shade No. 632 both inside and outside with powder coating. Enclosure shall have provision for pad locking arrangement. Detachable gland plate shall be provided for taking connections from distribution Box and transformer bushing terminal. The distribution box shall have Aluminium bus bar(covered with PVC Insulated tape) along with lugs fitted on bus bar for connecting two or more single core L.T. Aluminum Bunched Cable of size 16 sq.mm.

#### **17.4 Instruction and operation Manual**

The successful bidder shall be required to submit 5 copies of Instruction and Operation manual for each lot of 100 Transformers (or part thereof) supplied. This instruction manual should give complete details about the pre-commissioning tests/checks and the details of preventive maintenance.

#### **18.0 QUALITY ASSURANCE PLAN**

The purchaser intends to purchase Transformers only from Quality conscious manufacturers. Preference shall be given to those who possess ISO 9001 / 9002 Certification.

The bidder shall furnish the details in respect of following, in the schedule prescribed herewith this specification, failing which the offer is liable for rejection.

- a. List of testing equipment and instruments (with class of accuracy) available with tenderer for inspection, testing and checking the Transformers offered, as per tender specification in the schedule of testing facilities. The calibration details should also be included.
- b. List of machines/equipment/T&P available with the tenderer for manufacturing the Transformers, in the schedule of plant and machinery.
- c. Details of type tests conducted on the Transformers offered for supply in the schedule of type test.
- d. List of raw material components and sub-assembly to be used for manufacturing the equipment offered, in the schedule of raw materials and components.
- e. Statement giving list of important raw materials, names of sub-suppliers for the raw materials, list of standards according to which the raw material are tested. List of tests normally carried out on raw materials in the presence of Bidder's representative, copies of test certificates.
- f. Information and copies of test certificates in respect of bought out accessories.
- g. Level of automation achieved and list of areas where manual processing exists.

The bidder should possess adequate facilities for inspection and testing of the transformers, as per requirement of the relevant ISS and this specification. In case any supplier is found not having all the instrument /equipment required for testing, the offer shall be ignored. No borrowing of instruments/ equipment shall be allowed. Testing of the transformers shall also not be allowed at the works of any other manufacturer. However, testing may be allowed at any Government testing laboratory. Tenderers will have to produce documentary evidence for the purchase of AMORPHOUS/CRGO metal core laminations, transformer oil and Aluminium conductors.

**19.0 INSPECTION AND TESTING:**

i) The inspection and testing shall be conducted as per relevant clause of the general conditions of contract (Section II) at the place of manufacturer. The transformers shall be completely assembled and tested at the factory. The inspection may be carried out by the purchaser at any stage of manufacturing. The supplier shall grant free access to the purchaser's representative at all reasonable times when the manufacturing work is in process. Inspection and testing of any material under this specification by the purchaser shall not relieve the supplier of his obligation of supplying the material in accordance with the specification and shall not prevent subsequent rejection if the material is found to be defective.

ii) The supplier shall afford the inspector representing the purchaser. All reasonable facilities, without charge, to satisfy him that the material is being manufactured in accordance with the specification. The bidder must have adequate set of instruments for conducting testing as per class of 0.5 or better. The instruments shall be duly calibrated and Calibration certificates should not be older than one year on the date of presentation to the Inspecting officer. The calibration shall be arranged from NABL accredited testing house only. Comprehensive lists of testing equipment / instruments indicating make, Sr.No. type of accuracy, calibrating agency, calibration date etc., should be furnished also with the bid. The calibrated instruments shall be duly sealed by calibrating agency to avoid any tampering with calibration and the details there of shall be clearly mentioned in the calibration certificate(s).

iii) The supplier shall keep the purchaser informed in advance, about the manufacturing programme so that arrangement can be made for inspection. The supplier shall give minimum fifteen days advance intimation to enable the purchaser to depute his authorized representative for stage inspection / witnessing of various tests on the equipment / material as detailed below:

**NOTE:- Penal provision shall be made for any short technical parameters found / noticed in the transformers at any time even beyond guarantee period.**

**20.0 TESTS:****20.1 Routine / Acceptance Tests:**

- A) 100% testing of the Distribution Transformers shall be carried out at firm's works for measurement of total load losses at 50% & 100 % loading. Remaining testing shall also continue to be carried out as per practice.
- B) All the assembled / finished transformers prior to dispatch shall be subjected to all the Routine Tests as per IS: 2026. Minimum 25% of the lot size samples for Routine tests & checking shall be selected by the inspecting officers at random subject to minimum five (5) Nos. The supplier shall invariably furnish manufacturer's Routine test certificates along with inspection call of the offered transformers for pre-despatch inspection.
- C) The selected transformer samples shall be subjected to the following Routine / Acceptance Tests at the manufacturer's works in accordance with relevant ISS with latest amendments :
  1. Measurement of Voltage ratio.
  2. Measurement of No load losses & No Load current at 100% and 112.5% of rated voltage and normal frequency.
  3. Measurement of load losses at rated voltage and normal frequency (at 50% & 100% loading).
  4. Measurement of Impedance voltage at rated current and normal frequency.
  5. Measurement of windings resistance cold (at or near the test bed

- temperature).
6. Insulation resistance.
  7. Induced over voltage withstand test.
  8. Separate source voltage withstand test.
  9. Pressure Test(As per IS 1180 Part-1:2014)
  10. Oil leakage Test(As per IS 1180 Part-1:2014)
  11. Checking of rating and terminal marking plate.
  12. Checking of weights, dimensions, fittings and accessories, **creep age distance of HV& LV bushings**, tank sheet thickness, oil quantity, material, finish, paint thickness and workmanship as per purchase order and contract drawings.
  13. Physical verification of core – coil dimension, internal clearances, provisions of required oil ducts in the HV and LV winding, conductor sizes, individual weights of HV and LV winding core laminations etc., with reference to contract drawings and type test report(s) by dismantling selected unit(s). The physical verification shall be conducted on units equivalent to one unit per 50 Nos. or part thereof of offered quantity randomly selected from the offered lot. The dismantled unit(s) after reassembly shall be accepted by the purchaser after routine testing in presence of his representative.

**During final inspection, sheet thickness shall also be measured of the transformer opened for physical verification. The instrument for measurement of sheet thickness will be provided by the supplier.**

14. Oil dielectric strength (break down voltage) test shall be carried out on the transformers opened for physical verification and average value shall be calculated.
  15. Checking of manufacturer's test certificates shall be done and copies thereof duly signed by firm's representatives and inspecting officers shall be enclosed with the inspection report.
- D. Invoices of Amorphous/CRGO core material shall be provided by the supplier to the inspecting officer at the time of inspection and same shall be verified by the inspecting officer.
- E. It will be mandatory for the manufacturer firms to maintain record of BDV value of the transformer oil and shall furnish to the inspecting officer who in turn shall furnish the same to the Nigam's CTL for verification purpose. The Inspecting Officer during inspection shall verify record of Meggar value of the offered DT's and furnish the same with inspection report to the Nigam's CTL. Simultaneously, record of Air Pressure Test shall also be checked by the inspecting officer and same be furnished with report to the CTL. CTL will conduct testing of DT's only after receipt of record of BDV value, Meggar value and air pressure test results.
- F. The following tests shall also be carried out at manufacturer's works on one complete unit of 5 KVA:

**Salt spray test and Hardness tests as per the relevant standards.**

- G. Fifteen days clear notice shall be arranged for predispatch inspection by Purchaser's representative as per General Conditions of Contract.
- H. After successful inspection, the inspecting officer shall seal all the inspected transformers by tamper proof polycarbonate seals **on top cover bolts** of the

transformer for identification. Before sealing the inspecting officer will ensure that all the offered transformers are complete and duly fitted with name, rating and diagram plate, identify plate and identification marks, as specified in this specification.

- I. The oil leakage test shall be conducted on transformer complete in all respects shall be tested at a pressure equivalent to twice the normal head at the base of tank for 6 hours. There should be no leakage at any point.

## **20.2 TYPE TESTS & SPECIAL TESTS:**

In addition to above tests the following type tests shall be arranged **on one transformer only as per IS :1180 (Part-1/2014)** in accordance with IS 2026 (Part 1 to III) with latest amendments, at laboratories accredited by National Accreditation Board/ Govt. approved lab for testing and calibration laboratories (NABL).

### **(a) SHORT CIRCUIT TEST FOR DYNAMIC AND THERMAL ABILITY:**

The Short circuit test for dynamic and thermal ability shall be arranged on one unit of each rating. The transformers for the test shall be selected /sealed by our inspecting officer from the first lot which shall be of minimum 20 Nos. (if ordered quantity is 500 Nos.) OR 50 Nos. (if ordered quantity is more than 500 Nos.). The Short Circuit test shall be conducted only after successful Routine tests including measurement of No Load and Load Losses (at 50% & 100% loading). The supply shall be accepted only after arranging successful type test on the selected transformer(s).

### **(b) IMPULSE VOLTAGE WITHSTAND TEST:**

The Impulse Voltage withstand test as per clause No. 13 of IS:2026 (Part-III) – 1981 shall be arranged. Impulse voltage withstand test shall be **Minimum 75KVp** for 11 KV class transformers. The test shall be conducted on one unit of each rating to be selected by our inspecting officer from the first lot of minimum 20 Nos. (if ordered quantity is 500 Nos.) OR minimum 50 Nos. (if ordered quantity is more than 500 Nos.). The supply shall be accepted only after arranging successful Impulse test on the selected transformer(s).

**Note :-**If ordered qty. Is less than 500 Nos. In such case first lot shall be of min. One month qty as per scheduled delivery .

### **(c) TEMPERATURE RISE TEST:**

**Temperature rise test shall be conducted on Maximum measured total loss (No load at rated excitation+Load loss at max. current tap at 75°C) at 100% loading shall be supplied during temperature rise test** at a Govt. approved/ a Govt. recognized/ NABL accredited laboratory/ILAC i.e. International Laboratory Accredited Laboratory/ ILAC i.e. International Laboratory Accreditation Cooperation (in case of foreign laboratory).

The transformer shall be capable of giving continuous rated output without exceeding the specified temperature rise. Bids not meeting the above limits of temperature rise will be treated as non responsive.

**d) PRESSURE TEST:( As per IS 1180 (Part 1):2014)**

This test shall be conducted as type test at a Govt. approved/ a Govt. recognized/ NABL accredited laboratory. The pressure gauge shall be duly calibrated and sealed by an independent recognised test lab(s).

The test procedure shall be as detailed below :

**The tank subjected to air pressure of 100 KPa above atmospheric pressure for 30 min. There should be no leakage at any point and is no deformation of tank.**

No extra time shall be allowed for arranging these type tests. The cost of above Type Tests shall be borne by the supplier.

The programmed indicating date and place of type test(s), be intimated enabling purchaser to depute his representative to witness the test if desired. The testing house shall be advised to arrange type test result directly alongwith drawings duly attested by the testing authority for our scrutiny and approval. The type-tested transformer(s) shall also be accepted as the part of the supplies.

The requirement of arranging above type tests shall however not to be insisted on the suppliers who have arranged the above type tests within last 5 years from the date of opening of this tender on similar design. Minor changes in the present specification will not necessitate repetition of type test(s), if design of core-coil assembly is similar in essential details.

**21.0 RANDOM SELECTION AND TESTING (RST):**

21.1 The purchaser may select transformer(s) from the supplied lot(s) at random from the stores for conducting the following type tests, at any test house(s) as mentioned above. The supplier shall arrange these tests including loading, unloading and to & fro transportation from our stores to the test house(s). The charges for such tests shall be reimbursable to the supplier on actual basis on production of documentary evidence in case the selected sample successfully withstand type test(s) In case of otherwise, no charges will be reimbursed.

- i. Short circuit withstand test for Dynamic & Thermal ability. Measurement of No load & load Losses at 50% and 100% loading shall form part of tests conducted before and the after the short circuit test and recorded in the report.
- ii. Impulse test as per Clause No.13 of IS:2026 (Part-III). Impulse voltage shall be **Minimum 75 KVp**.
- iii. Temperature Rise Test as per IS 2026 Part 2
- iv. Pressure Test as per IS 1180 Part-1:2014
- v. Purchaser reserves the right to carry out any site tests he may decide upon at his own expenses. In case equipment/ material are not found as per P.O., all expenses incurred during the testing will be to supplier's account and material shall be replaced by the supplier at site free of cost.

**21.2 FAILURE IN TYPE TEST(S):**

In the event of failure / unsatisfactory results of the transformer(s) in short circuit test / impulse type tests/ Temperature rise Test/ Pressure Test, the

supplier shall have to replace the supplies already made and no further transformers shall be accepted. The purchaser however, at his option, may accept the transformers already supplied with the following conditions-

- i) Guarantee period of the supplied transformers issued to the field shall be increased by double the normal Guarantee period.
- ii) Bank Guarantee shall be extended to cover the additional Guarantee period.
- iii) For failure in any of the type tests listed under RST i.e., short circuit test / Temperature rise Test/ Pressure Test& Impulse withstand test, no further supplies shall be accepted. The type test charges shall also not be reimbursable in this case and shall be borne by the supplier.
- iv) The transformers lying in the store(s) shall be replaced as per sub para (v) below.
- v) The bidder shall, however, be allowed to check the reasons of failure and if need be, to improve / modify the design. Further supplies, including replacements against supplies already made, shall be accepted only after successful type test(s) are arranged on fresh transformer(s) selected by the authorized representative of the purchaser. All the type tests shall be arranged in case there is change in the design, otherwise, type test shall be repeated only for the test in which failure has occurred. Charges for such test(s) shall be borne by the supplier. However, in the event of failure of transformer in the repeat type test, the purchaser may take following actions:
  - a) Cancel pending orders of the rating in which failure(s) has occurred, &
  - b) Not place any order of Distribution Transformers on the firm for one two year(s).

### **21.3 Measurement of Total Losses (at 50% & 100% loading):**

(i) After pre-dispatch inspection of material at firm's works, the dispatch instructions will be issued for the respective store(s) as per requirement of Nigam. Sample(s) will be drawn from the lot(s) received in store(s) and will be subjected to the following test(s):

- b) One transformer will be selected out of every lot of 10 Nos. or part thereof for measurement of No load Losses at rated voltage; No Load current (at 100% and 112.5% of rated voltage); Impedance voltage, thickness of tank body sheet and total Losses at 50% and 100% loading at rated current. The testing shall be arranged either at purchaser's own testing lab and / or at independent test lab. The testing charges for such tests shall be borne by the purchaser. The test results will be applicable to the respective lot of 10 Nos. from which sample was drawn.
- c) In case if dispatch instructions are less than 10 Nos. than one sample shall be selected from each store (s) and the test result so obtained shall be for the quantity consigned / received by the store (s).

The percentage impedance voltage at rated current shall not exceed the permissible limit as specified with allowable tolerance failing which the sub lot of transformers represented by the sample shall be rejected. The transformers selected for total Losses

shall also be subjected to magnetizing current and in case found beyond the limit, the lot shall stand rejected.

The I.R. values of the sample(s) shall be measured at CTL, Jodhpur and it must be more than 50 MEGA-OHM.

**One sample out of 100 Nos. transformers or part thereof (randomly selected by CTL) shall be selected for physical verification/ checking of window height and checking of insulation of HV and LV windings, make of Inbuilt circuit breaker size of lugs and size of PVC Copper cable at CTL.**

**Metal Parts of Bushing assembly shall be checked in CTL as per specification/IS on the transformer which is physically opened in CTL (from the lot of 100 Nos. or part thereof). The tolerance may be allowed in accordance with coarse class of IS 2102-1969. If sample does not confirm the requirement of specification/IS, then lot of 100 nos. or part thereof shall be rejected.**

**The No load voltage ratio (Transformer Turn Ratio) shall be checked in CTL with the tolerance as per specification/IS 2026 on the transformer from the lot of 10 nos. or part thereof and the concerned sub lot shall be rejected if not meet out the requirement of IS.**

**The sample of Oil be taken at CTL from the Transformer opened for physical verification in presence of firm's representative and same shall be tested at Nigam's CTL/NABL accredited Lab. If sample does not confirm the requirement of specification, then lot of 100 nos. or part thereof shall be rejected**

**Further, Internal clearances shall be checked without opening of core coil assembly in each of the transformers which have been selected for physical verification at CTL (i.e. one sample from a lot of 100 nos. or part thereof) in presence of firm's representative. No negative tolerance shall be admissible. If clearances are not found as per specification then the lot of 100 Nos. or part thereof shall be rejected.**

**Besides above points following shall also be checked in CTL opened for physical verification and if the sample(s) does not meet the above requirements then the entire lot shall be rejected:**

- 1. Marking on HV terminals on transformer tank by stamping (i.e. HV phase terminal as 1.1 , HV neutral terminal as 1.2).**
- 2. Marking on LV terminals on transformer tank by stamping (i.e. LV phase terminal as 2.1 , LV neutral terminal as 2.2).**
- 3. Marking on Outgoing LV terminals of M&P Box by stamping (i.e. LV phase terminal as 2.1 , LV neutral terminal as 2.2).**
- 4. Earthing of core through tinned copper earthing Foil of 25 mm width & 1 mm thickness bolted on core clamp, after removing the channel paint.**

**NOTE:**

If the total losses are found more than 10% of specified losses at 100% loading then apart from rejecting the lot, firm's balance order would be cancelled and such firms shall not be awarded any order for one year or in next tender of tendered rating to be opened / finalized whichever is later.

The tolerance in window height shall be  $\pm 2$  mm, If the window height found beyond  $\pm 2$  mm but up to 7.5 mm then the lot shall be rejected. However if the window height is found more than 7.5 mm, then apart from rejecting the lot, firm's balance order would be cancelled and such firms shall not be awarded any order for one year or in next tender of tendered rating to be opened / finalized whichever is later.

**NOTE:** Payments shall be made only after receipt of successful test report from our Central Testing Laboratory (CTL) on the samples selected from the material received at the stores, however, the payment priority shall be maintained from the date of



submission of bills alongwith receipted challans to the Accounts Officer (CPC), JdVVNL, Jodhpur.

If the contractor / supplier fails to lift the material declared rejected or any part thereof from the consignee within a period of 15 days from the date of dispatch of information from the purchaser, the purchaser shall be entitled to effect recovery along with other actions as per Clause No. 1.62 of Section-II (General Condition of Contract).

#### 21.4 **CHALLENGE TESTING CLAUSE:**

The other manufacturer who have either participated in the instant tender enquiry can request challenge testing for tests covered in this clause based on specification & losses. The challenger would request for testing with testing fee. The cost of to & fro transportations of all transformer tested under the provision of this clause along with loading & unloading and transit insurance at actual shall be borne by Challenger firm. The challenge testing fees shall be at least three times the cost of testing. The challenger would have the opportunity to select the sample from the store. The party challenged ,challenger& the utility could witness the challenge testing. The challenge testing would cover the

- i. Measurement of Magnetizing current
- ii. No Load Losses test
- iii. Load Losses test
- iv. Temperature Rise Test.

The challenge test could be conducted at any Govt. / NABL accredited Lab. like ERDA /CPRI. If the values are within limits as per specification including tolerance allowed in CTL, the products gets confirm else not confirmed. If the product is not confirmed, the manufacturer will pay the challenge fee and challenger would get the fee refunded. However, as a redressal system, the manufacturer (challenged firm) would be allowed to ask for fresh testing of two more samples from the store and the same be tested in a NABL/Govt. laboratory in presence of party challenged, challenger & the utility. If any one or both sample does not confirm the tests then the product is said to have failed the test. In such cases, the manufacturer (challenged firm) will be declared as unsuccessful manufacturer for the said product and balance supply shall not be availed and the balance order shall be cancelled with levy of maximum penalty. Firm shall also be debarred for one year or participating against next tender for that rating, whichever is later. The transformers already supplied (including tested in challenge testing) shall be accepted with the following conditions:

- i. Guarantee period of the supplied Transformers shall be increased by double the normal guarantee period.
- ii. Bank guarantee shall be extended to cover the additional guarantee period.

#### 22. **PRICE:**

The prices shall be quoted on F.O.R. destination basis in the manner detailed in schedule of prices (BOQ) indicating details of **ex-works price, freight & insurance charges, and CGST and SGST or IGST** for delivery at our stores. The quoted prices shall be variable as per IEEMA price variation formula attached herewith at **Schedule-II**, without any ceiling for distribution transformers. The base date for price variation shall be **01.06.2020 irrespective of date of tender opening..** The prices shall be

quoted after considering modvat benefits & benefit of VAT available to the supplier. The offers where the prices have not been quoted in prescribed manner are liable for rejection.

**The bidder shall submit transformer cost analysis sheet along-with the tender-including the cost of raw materials, overhead expenses, estimated profit, etc., for each rating separately, as per the annexure attached with the specification. In case the cost analysis sheet is not enclosed Nigam may consider to ignore such offers.**

**NOTE:** Payments shall be made only after receipt of successful test report from our Central Testing Laboratory (CTL) on the samples selected from the material received at the stores, however, the payment priority shall be maintained from the date of submission of bills alongwith receipted challans to the Accounts Officer (Cash &CPC), JDVVNL, Jodhpur.

### **23. GUARANTEE PERIOD:**

I. Performance guarantee of the transformer(s) with LT protection unit shall be for the period of 36 (Thirty Six) months from the date of dispatch. The date of expiry of guarantee period shall be marked on the rating plate. Transformer(s) alongwith LT protection unit failed within such guarantee period shall have to be **repaired / rectified** free of cost expeditiously.

**Note:**

- I. **The firm will repair all type of G.P. failed Distribution transformers without asking any segregation on account of manufacturing defect. However, the Discoms will compensate the cost of missing parts as per practice in vogue.**
- II. **The guarantee period failed transformers will directly be lifted by the supplier from the respective circle store within a period of 60 days from the date of intimation by the respective consignee and will repair Distribution Transformers against G.P. failed within 30 days from the date of lifting in the ACOS / Central Store, if operative, along with the joint inspection sheet of missing parts issued by the respective consignee. After receiving the material at ACOS / Central Store, the same shall be tested at CTL as per provisions of the relevant contracts and will be issued to the circle store as per requirement of Nigam's account. The invoice of missing parts shall be verified by the ACOS as per the joint inspection sheet issued by the circle store as per practice in vogue and accordingly, the Sr. AO (Cash & CPC) will make the payment of missing parts, if any.**
- III. **The loading of G.P. failed Distribution Transformers at circle store and unloading at ACOS will be on supplier account.**
- IV. **The firm will repair G.P. failed transformers irrespective of breakage of body seals as well as physical damage of transformer tank body due to bursting. The period during which transformer remained defective / failed will not be accounted in the performance guarantee period. The period of defective will be reckoned from the date of first intimation (i.e. field officer / Consignee whichever is earlier) to date of delivery of repaired transformer.**
- V. **Firms shall lift the G.P. failed Transformer(s) within a period of 60 days from the date of intimation by the respective consignee and will repair Distribution Transformers against G.P. failed within 30 days from the date of lifting positively. In case firm fails to deliver repaired Transformer(s) within 90 days from date of intimation, the cost of the transformer(s) shall**

be withheld from firm's financial hold and in case firm fails to deliver repaired within 90 days from date of intimation, a penalty at the rate of  $\frac{1}{2}\%$  per week subject to maximum 10%, shall be levied for the late delivery of repaired Transformer(s).

Firm shall lift G.P. failed transformers after furnishing safe custody bank guarantee, the slab of safe custody Bank Guarantee shall be as under.

## II Safe custody Bank Guarantee :-

**Safe custody Bank Guarantee (SCBG) not to be taken from those supplier firms whose available financial hold in the form of composite Bank Guarantee(s) is more than the amount of SCBG as per following slab:**

**In case if order is upto 1000 Nos. DT's the firm have to give safe custody Bank Guarantee for Rs.5.00 Lacs and if order is more than 1000 Nos. but upto 3000 Nos. then the safe custody BG for Rs.10.00 lacs and for orders more than 3000 Nos. DT's the value of safe custody BG shall be Rs.20.00 Lacs. The safe custody bank Guarantee (SCBG) shall be of 1% of the value of the contract or as per above mentioned slab, whichever is lower.**

**The Safe custody Bank Guarantee (SCBG) be taken as per above mentioned slab from those supplier firms whose financial hold is not available in the form of Composite Bank Guarantee(CBG).If the available financial hold in the form of CBG is less than the SCBG amount as per above slab, than SCBG for the additional amount will be taken.**

**The Composite Bank Guarantee(s) equivalent to amount as per above slab shall only be released after fulfilling the contractual obligations by the firm regarding under guarantee period failed distribution transformers.**

**III All the repaired / rectified transformers by the manufacturer under guarantee clause shall carry a further guarantee of 12 months after repair or unexpired guarantee of 36 months from the date of supply, whichever is later, after repair / rectification. The bank guarantee equivalent to cost of repaired transformers shall be furnished after expiry of performance guarantee period to cover such repair guarantee. The purchaser also reserves the right to withhold the payment of supplier firm, under any other contract, if the performance of the supplier in repaired the failed transformers is not satisfactory. Each supplier shall invariably furnish the detailed information about the total number of transformers failed and repaired by them, every month after commencement of supplies.**

**IV In order to ascertain that transformers have successfully completed guarantee period the following details shall be provided on the transformer body:**

**A. A repair identification steel plate of size 75 x 75 x 2.5 mm duly engraved with following details shall be welded on the transformer body.**

Firm's Name / Logo  
 TN  
 KVA  
 Sr.No.

Date of supply

Ist time

IInd time

IIIrd time

Date of failure

Date of repair

Guarantee period  
extended.

**B.** Such metallic plate fixed on first **repair** should not be removed at the time of second **repair** or any subsequent **repair**. However, necessary details of failure and **repair** shall be graved on **the identification plate**, each time it is **repaired** in guarantee.

**C.** The **repaired G.P. failed** transformer shall be provided with 40 mm wide red color band all around transformers including radiator each time it is **repaired** in G.P. Thus if a transformer is **repaired** three time in G.P. then there should be three colored bands each of size 40 mm.

**V** All due care should be taken to ensure that the original name plate and identification plate provided should not be removed from the position at which they are fixed originally. In case it is felt that these are loose then it should be repaired suitably by welding or riveting.

**VI** Test checking of G.P. failed transformers will be allowed to the supplier at Nigam's store before lifting of G.P. failed distribution transformers to repair at supplier's works so that minor mistakes like loosing of connections/ replacement of fuse wire be carried out at Nigam's stores.

**VII** G.P. repaired Distribution may be got tested at CTL as per the sampling plan of new transformer except the physical opening test. The 10% tolerance (as per IS:2026 part -I/1977) be allowed on total losses at 50% and 100% loading for the transformers failed under guarantee period for testing at firms' works as well as in CTL testing.

**VIII An undertaking shall be furnished by the firms, who will supply the amorphous distribution transformers** that in case transformer fails beyond guarantee period, it shall be repaired by them on the rates, terms & conditions of Nigams existing CRC for repair of distribution transformers and in case firm denies to repair the transformers under CRC, such firms shall not be awarded order in subsequent tender.

**NOTE:-1. Firm shall keep the records for at least 8 years of transformers supplied by them.**

#### **24. DELIVERY SCHEDULE:**

The bidders are required to indicate the delivery period in the schedule attached herewith. The commencement period shall include the time taken for conducting the type test and approval of drawings etc. **The maximum commencement period should not be more than 45 days from the date of receipt of P.O. Further the monthly delivery quoted shall be such that the entire offered quantity shall be completed within a period of 10 months from date of receipt of P.O. including**

**commencement period. The offers deviating in deliveries as per above schedule given, shall be considered as non-responsive. The monthly delivery shall be quoted irrespective of the offered / ordered quantity and offers with any conditional deliveries shall be considered as non-responsive.**

## **25. PERFORMANCE SECURITY:**

Performance security shall be solicited from all successful bidders except the department's of the State Government and undertakings, corporations, autonomous bodies, registered societies, co-operative societies which are owned or controlled or managed by the State Government and undertakings of the Central Government. However, a performance security declaration shall be taken from them. The State Government may relax the provision of performance security in particular procurement or any class of procurement.

The amount of performance security shall be five percent of the amount of supply order in case of procurement of goods and services and ten percent of the amount of work order in case of procurement of works. In case of Small Scale Industries of Rajasthan it shall be one percent of the amount of quantity ordered for supply of goods and in case of sick industries, other than Small Scale Industries, whose cases are pending before the Board of Industrial and Financial Reconstruction (BIFR), it shall be two percent of the amount of supply order.

The bank guarantee shall be initially valid for 36 months and shall be further extended to cover the balance guarantee period whenever required by the purchaser. The performance bank guarantee shall be furnished in the prescribed Performa on a Rajasthan Govt. Non-Judicial stamp paper (where-ever applicable) amounting to 0.25% of the B.G value or Rs. 25,000/-, whichever is less. (It will also applicable on other type of Bank guarantee(s)). Outside the state of Rajasthan firms not furnishing the bank guarantee on non-judicial stamp paper of Rajasthan Govt. then they shall have to furnish difference amount of stamp duty on Non-Judicial stamp paper of Rajasthan Govt. You shall also furnish manufacturer's warranty on Rajasthan Govt. Non-Judicial stamp paper amounting Rs.500/- as per clause No.1.41.2(a) of GCC in the prescribed Performa.

## **26. QUANTITY:**

<b>Sr. No.</b>	<b>Item/ Rating</b>	<b>Quantity in Nos.</b>
1.	11/√3 KV / 240 V, 5 KVA RATING OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE <b>ALUMINIUM WOUND ENERGY EFFICIENT LEVEL-2</b> DISTRIBUTION TRANSFORMERS WITH INBUILT CIRCUIT BREAKER.	<b>11,280 Nos.</b>

**Note: 1. Price bids shall be opened only of the firms who are having "BIS Certificate" as on opening of technical bid.**

**2. Besides above changes, the technical parameters of the specifications wherever are deviating from the IS:1180 (Part-I/2014), the same shall be in accordance with IS:1180 (Part-I/2014) and its latest amendments, if any and the changes where the IS:1180 (Part-I/2014) is silent for technical parameters, same shall be applicable as per Discom specification.**

**27. ADDITIONAL ORDER:**

Repeat orders for additional quantities, up to 50% of original ordered quantities, may be placed by the Nigam, on the same rates, terms and conditions given in the contract.

**28. Make of Brought Out Items:**

The Make of brought out items like Bushings, Transformer Oil, MCCB etc. other than Make specified in the specification/work order may be accepted if confirms to relevant IS with due approval of JdVVNL.

**29.** Every Micro, Small & Medium enterprises of Rajasthan shall be required to submit an affidavit in schedule-XI, along with duly filled bid document.

**Schedule - I****SCHEDULE OF REQUIREMENT**

**11/√3 KV / 240 V, 5 KVA RATING OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE ALUMINIUM WOUND ENERGY EFFICIENT LEVEL-2 DISTRIBUTION TRANSFORMERS WITH INBUILT CIRCUIT BREAKER UNDER SPECIFICATION NO.JDVVNL/SE/MM&C/E1A1/TN-1625.**

S. No	ITEM	QUANTITY
1	11/√3 KV / 240 V, 5 KVA RATING OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE <b>ALUMINIUM</b> WOUND <b>ENERGY EFFICIENT LEVEL-2</b> DISTRIBUTION TRANSFORMERS WITH INBUILT CIRCUIT BREAKER.	<b>11,280 Nos.</b>

**NOTE:**

**The quantities as mentioned in the schedule of requirements are tentative and may increase/decrease as per the requirement of the Nigam.**

**SCHEDULE- II**

PRICE VARIATION CLAUSE FOR ALUMINIM WOUND DISTRIBUTION TRANSFORMERS COMPLETE WITH ALL ACCESSORIES AND COMPONENTS (FOR SINGLE AND THREE PHASE OF RATINGS UPTO 2500 KVA AND VOLTAGE UPTO 33 KV) (BEE / ENERGY EFFICIENCY LEVEL AS PER IS:1180(PART-I): 2014) SUPPLIED AGAINST DOMESTIC CONTRACTS UNDER **TN-1625**

This price variation clause is applicable for 'Single Phase & Three Phase Aluminum Wound Distribution Transformers' for BEE / Energy Efficiency Level as per IS:1180 (Part-I):2014 of rating upto 2500 KVA and voltages upto 33 KV. The clause is to be used for domestic contracts.

The price quoted/ confirmed is based on the input cost of raw material / components and labour cost as on the date of quotation and the same is deemed to be related to prices of raw materials and all India average consumer price Index number for industrial workers as specified in the price variation clause given below. In case of any variation in these prices and index numbers, the price payable shall be subject to adjustment, up or down in accordance with following formula.

$$P = \frac{P_o}{100} \left\{ 10 + 19 \frac{AL}{ALO} + 30 \frac{ES}{ESo} + 13 \frac{IS}{ISo} + 4 \frac{IM}{Imo} + 11 \frac{TO}{Too} + 13 \frac{W}{Wo} \right\}$$

Wherein

- P** = Price payable as adjusted in accordance with the above formula.  
**Po** = Price quoted/ confirmed.  
**ALO** = Price of LME CSP Average of Aluminium (refer notes)  
This price is as applicable on the 1<sup>st</sup> working day of the month, one month prior to the date of tendering.  
**ESo** = Price of CRGO Electrical Steel Lamination (refer notes)  
This price is as applicable on the 1<sup>st</sup> working day of the month, one month prior to the date of tendering.  
**ISo** = **Price of HR coil of 3.15 mm thickness** (refer notes).  
This price is as applicable on the 1<sup>st</sup> working day of the month, one month prior to the date of tendering.  
**Imo** = Price of insulating Materials (refer notes)  
This price is as applicable on the 1<sup>st</sup> working day of the month, one month prior to the date of tendering.  
**Too** = Price of Transformer Oil (Refer notes).  
This price is as applicable on the 1<sup>st</sup> working day of the month, one month prior to the date of tendering.  
**Wo** = All India average consumer price index number for industrial workers as published by the Labour Bureau, Ministry of Labour, Govt. of India (Base 2001=100)

This index number is as applicable on the first working day of the month, three months prior to the date of tendering.



For example, if date of tendering falls in December, 2015, applicable price of Aluminium (AL) and Transformer Oil (TO), CRGO Steel Sheets (ES), HR Coil (IS) and insulating material (IM) should be as on 1<sup>st</sup> November, 2015 and all India average consumer price Index number (W) should be for the month of September, 2015.

The above prices and indices are as published by IEEMA vide circular reference number IEEMA (PVC) / DIST\_PWR\_TRF/-/- one month prior to the date of tendering.

- AL** = Price of LME CSP Average of Aluminium (refer notes)  
This price is as applicable on the 1<sup>st</sup> working day of the month, one month prior to the date of delivery.
- ES** = Price of CRGO Electrical Steel Lamination (refer note)  
This price is as applicable on the 1<sup>st</sup> working day for the month, one month prior to the date of delivery.
- IS** = **Price of HR coil of 3.15 mm thickness**(refer notes)  
This price is as applicable on the 1<sup>st</sup> working day of the month, one month prior to the date of tendering.
- IM** = Price of insulating Materials (refer notes)  
This price is as applicable on the 1<sup>st</sup> working day of the month, one month prior to the date of delivery.
- TO** = Price of Transformer Oil (refer notes)  
This price is as applicable on the 1<sup>st</sup> working day of the month, one month prior to the date of delivery.
- W** = All India average consumer price index number for Industrial workers, as published by the Labour Bureau, Ministry of Labour, Govt. of India (Base 2001=100). This index number is as applicable on the first working day of the month, three months prior to the date of delivery.

For example, if date of delivery in terms of clause given below falls in Dec. 2015, the applicable price of aluminium (AL) and Transformer Oil (TO), CRGO steel sheets (ES), HR coil (IS) and insulating material (IM) should be as on 1<sup>st</sup> Nov. 2015 and all India average consumer price index number (W) should be for the month of Sept. 2015.

The above prices and indices are as published by IEEMA vide circular reference number IEEMA (PVC) / DIST\_PWR\_TRF/-/- one month prior to the date of delivery. The date of delivery is the date on which transformer is notified as being ready for inspection / despatch (in the absence of such notification, the date of manufacturer's despatch note is to be considered as the date of delivery) or the contracted delivery date (including any agreed extension thereto), whichever is earlier.

The claim of price variation shall be governed as per the Clause No. 1.10.2 of Instructions to Bidders.

**NOTE- The Base date will be 01.06.2020 irrespective of date of tender opening.**

**SCHEDULE II A****PRICES & PRICE VARIATION**

- a) The prices quoted shall be variable as per Price Variation Formula given in the Specification (Schedule-II) without any ceiling.
- b) If the price variation formula/**Indices** is changed, the same shall be applicable for the price variation. During the transit period when both old and new indices are being circulated, then the admissible Price Variation shall be applicable, which is advantageous to Nigam, and the period from which the old indices are discontinued then the P.V. shall be admissible with the new indices.
- c) The date of delivery applicable for claiming price variation shall be the date prevailing on the first day of Calendar month which shall be determined in the manner prescribed hereunder:-
- (i) When the material is offered within stipulated delivery schedule : For allowing P.V. the date of delivery shall be considered the date on which material is notified as being ready for inspection or date of receipt of inspection call in the office.
- (ii) When the material is offered after expiry of stipulated delivery schedule : For allowing P.V. in the cases supplies are made after the expiry of scheduled delivery, the price prevailing in the last month of the stipulated scheduled delivery or the date on which material is notified as being ready for inspection or date of receipt of inspection call in the office, whichever is beneficial to Nigam shall be allowed.
- (iii) When the material is offered ahead of delivery schedule on the request of JodhpurVidyutVitran Nigam Limited : Normally supplies ahead of delivery schedule shall not be accepted. However in case of urgency of material, if supplies are accepted ahead of delivery schedule, PV shall be allowed on the basis of the material is notified as being ready for inspection or date of receipt of inspection call in the office.
- (iv) When the material is offered ahead of delivery schedule by firm at their own and accepted by Nigam on the request of firm: Normally the request of the firm to accept the material ahead of delivery schedule will not be accepted. In case firm offers supplies ahead of delivery schedule at their own and such request is accepted by Nigam, the price prevailing in the last month of stipulated delivery schedule or the date on which material is notified as being ready for inspection or date of receipt of inspection call in the office, whichever is beneficial to Nigam shall be allowed.

**Schedule – III**

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**  
**A Govt. of Rajasthan Undertaking**  
**Prescribed technical specification for supply of**  
(Name of Material/Equipment/Machinery/T&P etc.)

S.No.	Technical specification to which material/equipment/ Machinery/T&P shall confirm	Name of IS/other standard specification to which material should confirm	Other particulars If any.
-------	--	---	------------------------------

Certified that we agree to all the aforesaid technical specification except at S.No.....  
for which our technical specification shall be as under:-

S.No.	Technical specification to which material/equipment/ Machinery/T&P shall confirm	Name of IS/other standard specification to which material should confirm	Other particulars If any.
-------	--	---	------------------------------

**(Signature)**

Name & Designation  
with seal of the bidder.

**SCHEDULE-III-A****QUALIFICATION REQUIRMENT FOR 11/ $\sqrt{3}$  KV / 240V 10 KVA RATING OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE ALUMINIUM WOUND ENERGY EFFICIENT LEVEL-2 DISTRIBUTION TRANSFORMERS WITH INBUILT CIRCUIT BREAKER AGAINST TN-1625**

The bidder should fulfill following qualifying requirements for successful participation in the tender along with relevant documentary evidence supporting each qualifying requirement without which the offer shall be considered non-responsive & rejected.

- I. The bidder should be a manufacturer of offered items. The offers from sole selling agent/ authorized dealers shall not be entertained.
- II) The bidder is required to quote for **minimum 10%** of tendered quantity, failing which the offer may be considered Non-Responsive.

**III) The bidder should have designed, manufactured / fabricated, tested and supplied to Licensed Power Utility/Discoms/Govt. Departments Distribution Transformers at least 2XQQ (QQ being the quoted quantity) of similar or higher rating in last three financial years** from the date of opening of techno commercial bid (For quantity verification C.A. Certificate should be furnished in prescribed Proforma as per schedule-VII(A)). However, this will not be applicable for transformers having different number of phases i.e. quantity supplied in three phase transformers will not be considered for single phase and vice-versa.

The material supplied and accepted for same/higher rating for turnkey projects to a licensed power utility/Govt. Shall be considered for the purpose of evaluating criteria. The certificate given by C.A. shall indicate above separately.

Note:-The CA Certificate should be furnished on the letter head of CA and must be signed by the bidder and C.A. firm. The details i.e. address of C.A. & membership No. shall clearly be mentioned on C.A. certificate. In case C.A. certificate is not signed by the bidder/furnished without membership No. & address of C.A. then same may not be considered for which responsibility rests with the bidder.

In support of fulfillment of the past supply criteria, the bidder shall furnish documentary evidence in the form of certificate from Chartered Accountant in the enclosed prescribed proforma only. This prescribed proforma should be furnished either in original or copy duly attested by Notary. The bidder shall also sign and affix seal on the C.A. Certificate. The certificate should have membership number with the name & address of the chartered accountant. Certificate should clearly indicate the quantity supplied, period of supply, voltage Class, Rating of the Transformer etc. in the format prescribed, any deviation to format or information diverted format, will not be considered and rejected.

- IV) The BIS is must for participation in the bid along with the type test reports of offered type and design which should not be older than five years as on date of opening of technical bid. The type test should be conducted on one unit i.e. Short Circuit Withstand Test, Lightning Impulse Voltage Withstand Test, Temperature Rise Test and Pressure Test as per IS:1180 (Part-I)/2014 .The firm will furnish Type Test SBG of Rs.5.0 lac in lieu of non furnishing of Type Tests Reports of offered type &

design . The firm will also furnish the inclusion of offered rating in the BIS Certificate before commencement of supply.

**Note: The price bid of only those bidders shall be opened whose BIS Certificate is valid as on the date of opening of Technical Bid. However, if the BIS License validity is expired as on date of opening of technical bid then the bid may be considered if BIS License is operative as on date of opening of technical bid and firm furnish the proof of deposition of renewal fee to BIS on or before expiry date of validity of BIS license.**

V) The bidder shall furnish valid type test certificates of same rating of offered item from a Govt. approved/Govt. recognized/NABL Accredited laboratory/ILAC i.e. International Laboratory Accredited Laboratory (in case of foreign laboratory). Such type test certificates should not be older than 5 years as on the date of opening of tender. For this purpose date of conducting type test will be considered. The date of conducting type test shall be before the date of opening of technical bid. Type test conducted at supplier's own NABL accredited lab shall not be considered. The following Type Test shall be conducted on one unit at NABL/Govt. Approved Lab as per IS:1180 part-1/2014 (Details of Test given in the specification)

- a. Lightning Imp. Voltage Test at Min 75 KV
- b. Short Circuit Test
- c. Temperature Rise Test
- d. Pressure Test.

VI) In case the bidder is not in a position to furnish type test certificate of same rating of offered item and furnish type test certificate of higher rating from CPRI/independent NABL Accredited laboratory/Govt. approved lab (which does not belong to tenderer) at the time of submission of bid, the bid of the bidders may be considered as responsive, if bidder gives an undertaking along with BG/DD/Pay Order that type test of rating offered shall be arranged from first lot (without asking for any delivery extension) from CPRI/independent NABL accredited lab or shall furnish the valid type test reports before commencement of supply from ERDA/CPRI/independent NABL Accredited laboratory/Govt. approved lab.

The bank guarantee from a Scheduled Bank/DD/Pay Order should be for an amount of Rs.5.0 Lacs towards furnishing of satisfactory type test reports from first lot (without asking for any delivery extension) or shall furnish the valid type test reports before commencement of supply. However In case the bidder fails to furnish successful type test certificates from the offered lot(s) or shall not furnish the valid type test reports before commencement of supply , their bank guarantee/DD/Pay Order will be invoked/forfeited (Proforma for submitting undertaking a bank guarantee is enclosed at Schedule-III C. The initial validity of B.G. shall be nine months with a grace period of 3 months.

**The firms may furnish the Type Test Reports of offered type & design or of higher rating with a Bank Guarantee of Rs.5.0 lacs along with the Technical Bid. However, the date of issuing of Type Test Bank Guarantee in lieu of non-furnishing of Type Test reports shall be before the date of opening of technical bid & the Type test BG issued on or after opening of technical bid shall not be accepted.**

**Note:-New state units & also those units located in Raj. Which do not meet Qualifying Criteria may be considered for trial order subject to technical competency and furnishing of BG of Rs. 5.00 Lacs in lieu of non furnishing of Type test report of offered items and design but BIS Certificate must be valid as on date of opening of Technical Bid failing which the bid shall be considered Non-Responsive.**

VII) The bidder should possess adequate testing facilities for carrying out routine & acceptance test of items as per relevant standard at their works. The bidder shall furnish documentary evidence in support for conducting routine & acceptance test.

VIII) The bidder shall clearly indicate the deviations such as Technical Deviation & Commercial Deviations in the prescribed proforma only. The deviations indicated elsewhere in the bid shall not be accepted.

VIII) The bidder must clearly fill up each and every particular of Guaranteed Technical Particulars annexed with Technical Specification otherwise he will be responsible for Technical Non-Responsiveness.

VIII) The type test certificates shall be furnished either in original or copy duly attested by notary.

**IX) PERFORMANCE CRITERIA:-**

- i. If a bidder has supplied upto 50% of ordered quantity in previous tender upto date of opening of subsequent tender and scheduled delivery period expired, the bid of such bidder will not be opened in the Discom for that item.
- ii. However, if the supplies have been completed for a quantity more than 50% but not completed upto date of opening of subsequent tender and scheduled delivery period expired, the quantity equal to the quantity pending in previous tender for that item shall be reduced from the subsequent tender quantity to be allocated to the bidder.

**X) POOR RECORD OF PERFORMANCE AND DELIVERY:**

The bidder(s) who have been black listed **in any of the state Discom** or with whom business relations have been severed in Jaipur Discom shall not be considered. Severment of business relations will be done in case of following circumstances for the period and with the recovery mentioned against each:

<p>i)When vendor does not accept order awarded on its accepted price and terms and conditions and does not comply with contractual formalities.</p>	<p>Forfeiture of EMD/cancellation of vendor registration to recover amount of EMD along with severment of business relations for three years from the date of issue of order.</p>
<p>ii) When vendor complies with contractual formalities but does not commence supplies.</p>	<p>Levy of maximum recovery on account of delay in delivery along with severment of relations for a period of 2 years from the date of issue of order or in next two bids whichever is later along with forfeiture of EMD/cancellation of vendor registration.</p>

**XI )Black Listing:**

**(A) Black Listing of Firms-**

After having given Show Cause Notice of 30 days, and having established & cogent reasons for blacklisting of the firm as given below, the firm should immediately be blacklisted for a period of 5 years indicating reasons of doing so, in the letter itself,

and a copy of such blacklisting should be given to the firm, with the approval of CLPC:-

1. There are sufficient and strong reasons to believe that the supplier or his employee has been guilty of malpractices such as manhandling/misbehaviour with Government official by supplier or his partner/employee, bribery, corruption or abatement of such a offence in a position where he could corrupt Nigam's official, fraud, vitiating fair tender process including substitution of or interpolation in tender, mis-representation, pilfer-aging or unauthorized use or disposal of Nigam's material issued for specific work etc.
2. Where a supplier or his partner or his representative has been convicted by a court of Law for offences involving moral turpitude in relation to the business dealing or where security considerations including suspected disloyalty to the Nigam/state so warrant the blacklisting.
3. If the State Bureau of Investigation or any other authorized investigating agency recommends for blacklisting after completing the investigation.

**Note: - 1**

If a supplier after having tendered for a supply or after negotiations gives application voluntarily vitiating the fair tendering process, it shall also tantamount to malpractice.

**Note: - 2**

A Black listed supplier –

- (i) shall not be entitled for registration in any of the Discom
- (ii) shall not be awarded any supply order in future in any Discom during the notified period.
- (iii) his registration if any shall stand cancelled immediately and his registration security/EMD/S.D. shall stand forfeited.
- (iv) In case of blacklisting of the firm by any one of Discom for the cogent prescribed reason(s) as stipulated above, the same shall be applicable to all the three Discoms and as a consequence of blacklisting, all the pending orders to that firm, will be cancelled in all three (3) Discoms with immediate effect. However in respect of completed/executed contract G.P. obligations as well as other liabilities shall be fulfilled by the supplier.

**B. Severement of Business relation:**

After having given Show Cause Notice of 30 days, and having established & cogent reasons for Severement of business relation as given below, the firm should immediately be severed the business relations for a period of 2 to 3 years indicating reasons of doing so, in the letter itself, and a copy of such severement should be given to the firm, with the approval of CLPC:-

- i. The supplier continuously refuses to pay Nigam dues without showing adequate reasons and where the purchasing authority is satisfied that no reasonable dispute attracting reference to Settlement Committee or Court of Law exists for the supplier's action of non-supply.
- ii. When vendor does not accept LOI/detailed purchase order awarded on its accepted prices and terms & conditions or does not comply with the contractual formalities.

- iii. When vendor/supplier who otherwise completed contractual formalities but does not commence supplies on the date of opening of technical bid of the fresh tender/completion of schedule delivery period whichever is later.

**Note:-**

1. In case supplier does not deposit outstanding dues towards Nigam, even after completion of severement period, the period of severement will continue.
2. Severement done purely/ mainly on account of non-deposition of dues against the supplier/vendor/contractor could be lifted by CLPC, if the dues are deposited prior to the expiry of such severement period.
3. Severement done by one Discom for non-supply of material and /or corresponding non-recovery of dues will not be effective in other Discoms **except in respect of common purchase cases of Three Discoms.**
4. On severement of business, the EMD/SD/vendor registration security/Bid security will be forfeited.
5. The orders in execution satisfactorily will not be cancelled other than the order on which severement have been done.

**C. DEBARMENT:-**

Reasons on which Debarment can be made:-

- (i) The competent authority may debar the supplier on account of his performance or other disabilities, if it is no longer considered fit to remain under vendor registration as per his obligation under vendor registration.
- (ii) If at any subsequent stage of inspection of firms after award of contract, it is found that firm does not have sufficient tech. Staff or required/necessary technical equipment, the purchasing authority can debar the firm for one year or next tenders whichever is later. The debarment will be lifted only on re-inspection of firm's works; the defects noticed earlier are fully rectified to the satisfaction of Nigam.
- (iii) When contract agreement executed and supplies commenced but could supply only up to 50% of ordered quantity and scheduled delivery period expired, then the firm can be debarred for one year or next tender whichever is later in that Discom only for that particular item/rating/capacity/size etc.
- (iv) The suppliers who have been awarded contract for supply of material is not adhering to the periodic delivery schedule, the contract awarding authority reserve the right to terminate the contract and may debar the firm in participating in tender for a period of 2 to 3 years.

**Note:-1.** On debarment, the EMD/SD/Vendor Registration security/Bid security shall be forfeited.

**Note:-2.** If the firm is debarred in one Discom for any reasons then the same should not be applicable in other Discom **subject to exception that in case of common Discoms purchases such debarment of a firm would be applicable to all three Discoms for that particular item and rating/capacity/size etc.**

**XII) APPEALS AND APPLICATIONS:**

Appeal against the order of blacklisting, severement and debarment can be filed before BOD within a period of 3 months from the date of intimation. The letter of appeal will be addressed to the order placing authority. Who will process the case for placing the matter in B.O.D. with in a period 60 days. The BOD may reduce or waive the penalty, if sufficient reasons/supporting documents are furnished by the supplier.



**SCHEDULE – III -B**

**BANK GUARANTEE IN LIEU OF FURNISHING OF TYPE TEST CERTIFICATE**  
**UNDER TN-1625**

**(On Rajasthan Non-Judicial Stamp Paper worth Rs.1250/-)**

To,

The Superintending Engineer (MM&C)  
Jodhpur Vidyut Vitran Nigam Limited  
New Power House Premises,  
JODHPUR.

Dear Sir,

Whereas Jodhpur Vidyut Vitran Nigam Limited, Jodhpur (hereinafter called the Purchaser) has issued a tender enquiry under TN\_\_\_\_\_ for procurement of \_\_\_\_\_ (name of material).

Whereas M/s \_\_\_\_\_ (hereinafter called the bidder) has furnished a bid for supply of \_\_\_\_\_ to the Superintending Engineer (MM&C), Jodhpur Vidyut Vitran Nigam Limited, Jodhpur or his nominated officer(s).

Whereas in accordance with the provision of the specification of the aforesaid TN\_\_\_\_\_, the bidder can deposit a bank guarantee in lieu of the requirement of furnishing the type test certificates.

Whereas M/s \_\_\_\_\_ (the bidder) have requested us (Name of the Bank) to furnish the bank guarantee, in lieu of the type test certificate, for an amount equivalent to Rs.\_\_\_\_\_ (in words also) only.

Under this Bank Guarantee, we (Name of the Bank) hereby undertake unconditionally and irrevocably to guarantee as primary obligator and not as Surety merely, the payment to the purchaser on his first demand without whatsoever right of objection on our part and without his first claim to the bidder, in the amount not exceeding (amount of guarantee in figures and words).

Payment pursuant to this undertaking will be demanded by the purchaser from the Bank and will be met by the Bank without question in the case in which the bidder, on receipt of the order and/ or after the acceptance of this tender, makes default in furnishing the required type test certificates. As to whether the occasion or ground has arisen for such demand the decision of the Superintending Engineer (MM&C), Jodhpur Vidyut Vitran Nigam Limited shall be final.

The liability of the Bank shall not at any time exceed Rs.\_\_\_\_\_ (Rupees \_\_\_\_\_).

The undertaking will be determined on but will not withstanding such determination, continue to be in force till the expiry of 3 months from that date.

No indulgence or grant of time by the purchaser to the bidder without the acknowledgement of the Bank will discharge the liabilities of the Bank under this guarantee.

The guarantee herein contained shall not be affected by any change in the constitution of the bidder.

All disputes arising under the said guarantee between the Bank and the bidder or between the bidder and the purchaser pertaining to the guarantee shall be subject to the jurisdiction of Courts only at JODHPUR in Rajasthan.

The Bank further under take not to revoke this guarantee during its currency except with the previous consent of the Superintending Engineer (MM&C), Jodhpur Vidyut Vitran Nigam Limited, Jodhpur.

Notwithstanding anything contained herein before, the Bank's liability under this guarantee i.e. restricted to Rs. \_\_\_\_\_ (Rupees \_\_\_\_\_) and the guarantee shall remain in force upto \_\_\_\_\_. Unless demand or claim in writing is presented on the Bank within three months from that date, the Bank shall be released and discharged from all liabilities there-under. However, the validity of the bank guarantee shall be extended as and when required by the purchaser.

IN WITNESS WHEREOF the Bank has executed these presents the \_\_\_\_\_ day \_\_\_\_\_ month \_\_\_\_\_ and year \_\_\_\_\_.

Yours faithfully,

(Bankers)  
EXECUTANT

Witnesses:

1.

2.

**SCHEDULE-IV `A`****Must be filled-in by the tenderer and attach with technical bid (Part-I)**

To,

The Superintending Engineer (MM&C),  
JodhpurVidyutVitrان Nigam Limited,  
Jodhpur.

Dear Sir,

With reference to your invitation to tender against specification No. JDVVNL/SE/MM&C/TN-1625 we agree to supply the following quantity:-

S. N	Particulars of item	Tendered Quantity	Qty. Offered	Justification of quantity offered as per Qualifying Requirement.	Status of Type Test Certificates.
1	2	3	4	5	6
1.	11/√3 KV / 240 V, 5KVA OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE ALUMINIUM WOUND DISTRIBUTION TRANSFORMERS ENERGY EFFICIENCY LEVEL-2 WITH INBUILT CIRCUIT BREAKER	<b>11,280 Nos.</b>			

- The offer is valid for a period of 120 days from the date of opening of this tender.
- The base date of prices will be **01.06.2020** irrespective of date of tender opening.
- It is noted that the quantities as mentioned in the specification are approximate and we agree to supply any quantity as per your requirement.
- The delivery shall strictly be in accordance with our delivery clause as given in **Schedule-VIII** of this specification. In case we fail to deliver the material as indicated in the clause No. 1.23, we are liable to pay recovery for delay in delivery as per clause No. 1.24 of this Schedule-II of this specification. The material shall conform to your specification No. JDVVNL/SE/ MM&C/TN-1625 and as per relevant ISS in all respect.
- We confirm that we agree to all the terms & conditions as well as the technical stipulations of your specification No. JDVVNL/SE/MM&C/TN-1625 and there are no deviations other than as specified in the **Schedule VI (A&B)**.

Yours faithfully,

Signature of tenderer  
with stamp  
Dated

**Schedule – V**

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**

**A Govt. of Rajasthan Undertaking**

Statement of guaranteed technical particulars and other performance data for supply of ..... (Name of material) against specification no.....

---

S.No. Particulars of technical & other performance data guaranteed.

---

---

Certified that we agree to all the aforesaid technical particulars and other performance data except following :-

---

S.No.	Particulars of technical & other Performance data	Reasons for deviations/departure.
-------	---	-----------------------------------

---

---

**(Signature)**

Name & Designation  
with seal of the bidder

**Schedule -V(A)****MANUFACTURER'S GUARANTEED TECHNICAL PARTICULARS FOR 11/ $\sqrt{3}$  KV / 240 V, 5 KVA RATING OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE ALUMINIUM WOUND DISTRIBUTION TRANSFORMERS ENERGY EFFICIENCY LEVEL-2 WITH INBUILT CIRCUIT BREAKER AGAINST, TN-1625**

<b>S.No</b>	<b>DESCRIPTION</b>	<b>PARTICULARS</b>
	<b>Rating in KVA</b>	<b>5 KVA</b>
1	Name of the manufacturer and place of manufacturer	
2	Continuous max rating as per this specification (KVA)	
3	Normal ratio of transformer (KV)	
4	Method of connection HV/LV	
5	Max. Current density in windings a. High voltage Amp/Sq.mm b. Lower voltage Amp/Sq.mm	
6	Max hot spot temp Deg.C (Ambient air temp on which above is based Deg.C)	
7	a. Max. Observable oil temp in Deg.C (Ambient air temp on which above is based Deg.C)	
	b. Maximum winding temperature in Deg. C (Ambient air temp on which above is based Deg.C)	
8	ii) Total losses at normal voltage frequency, rated current and 75 Deg.C at 50% & 100% loading (Max).(watts)	
9	Flux Density(Max)(Tesla)	
10	Percentage no load current at rated frequency (without any positive tolerance) a) At rated voltage b) At 112.5% rated voltage	
11	Efficiency at normal voltage: Unity power factor At 50% load % At 75% load % At full load % ii 0.8 power factor a. At 50% load % b. At 75% load % c. At full load %	
12	Regulation as % of normal voltage a. At unity power factor % b. At 0.8 power factor lagging %	
13	Impedance voltage at normal ratio between HV and LV winding %	
14	Type of transformer, Shell type/Core type Wound core.	
15	Type of insulation used in a. HV winding b. LV winding	
16	Impulse test voltage level (KVrms) HV winding LV winding	
17	H V Bushing details:- (a) Rating of the bushing	

	(b) Impulse strength (c) Power frequency withstand voltage, dry and wet (d) IS reference (e) Make	
18	LV Bushing details :- (a) Rating of the bushing (b) Impulse strength (c) Power frequency withstand voltage, dry and wet (d) IS reference (e) Make	
19	Minimum External Clearances (in air as per IS:1180) i) HV phase to earth (mm)  ii) LV phase to earth (mm)	
20	Minimum Internal Clearances i) Clearance between inner wall of tank and coil (mm)  ii) Radial clearance between HV & LV windings (mm) iii) Radial clearance of LV coil from core (mm)  iv) End clearance of HV coil from Yoke (mm)  v) Minimum Gap between core & tank bottom for oil circulation (mm)	
21	<b>H V coil constructional details:-</b> (a) Conductor cross Section(min.) (b) Bare conductor size dia (c) Covered conductor size dia (d) Coill. D (e) Coil O.D (f) Coil axial length (g) Total no. Of turns per phase (i) Inter layer insulation	
22	<b>LV coil constructional details:-</b> (a) Conductor cross Section(min.) (b) Bare conductor size (min.) (c) Covered conductor size dia (d) Coill. D (e) Coil O.D (f) Coil axial length (g) Total no. Of turns per phase (i) Inter layer insulation	
23	Characteristics of transformer oil	
24	Total content of oil in litres	
25	i) Approximate overall dimensions  a. Height in mm b. Breadth in mm c. width in mm ii) Tank Internal dimensions  a) Diameter mm b) Height mm (iii) Tank sheet thickness (a) Sides (b) Top (c) Bottom	

26	Weight of insulated conductor a. HV (min) kg b. LV (min) kg	
27	Weight of core (min.) kg	
28	Weight of Fittings and accessories (Kg.)	
29	Weight of Oil (Kg.)	
30	Weight of complete transformer arranged for transport kg	
31	<b>Core Details:</b> i) Step Width ii) Stack Thickness iii) Cross sectional Area IV) Effective core Area v) Core Window Height	
32	Resistance for windings at 75 Deg.C per phase a. HV Ohms b. LV Ohms	
33	Material of bushing rod and nuts & Bushing caps HV LV	
34	Make , type of L.V Breakers	
35	Particulars of HV fuse	
a)	System voltage	
b)	Current	
c)	Max. Design voltage	
d)	Min. Melting time	
e)	Total clearing time	
f)	Interrupting rating	
g)	Mounting	
h)	Make	
36	<b>All the standard fittings &amp; accessories shall be provided as per IS:1180 ( part-1)-2014/spec.</b>	YES
37	Whether the metal parts of HV/LV Bushing are as per relevant IS and not under size (YES/NO). If Metal parts are under size, then the lot may be rejected at firm's works.	YES/NO
38	Whether the Each HV , LV & Neutral terminal shall be duly indelibly marked with its terminal numbers. (e.g. (e.g. HV phase terminal as 1.1 , HV neutral terminal as 1.2, LV phase terminal as 2.1 , LV neutral terminal as 2.2) by stamping with Min. Letter size of 40x40 mm. If No, then the lot may be rejected at firm's works.	YES/NO
39	Whether, the Lugs for LV terminal of transformer have been crimped with crimping tool and duly insulated. If No, then the lot may be rejected at firm's works.	YES/NO
40	Whether the gasket of LT Box is of one piece instead of pieces. If No, then the lot may be rejected at firm's works.	YES/NO
41	Whether the Core has been earthed through copper earthing foil of 25 mm width & 1 mm thickness bolted on core Clamp after removing channel paint. If No, then the lot may be rejected at firm's works.	YES/NO

42	Whether the Rating & Terminal Marking Plate is non-detachable & has been affixed with Min. 08 rivets (4 nos. on corners and 1 no. Each on width side and length side) and the base of the Rating & Terminal Marking Plate is continuously welded with the tank. If No, then the lot may be rejected at firm's works.	YES/NO
43	Whether the Internal electrical clearances in oil are found as per specification. If No, then the lot may be rejected at firm's works.	YES/NO
44	Whether all the External Electrical clearances are found as per specification. If No, then the lot may be rejected at firm's works.	YES/NO
45	Whether any core stamping found rusted & damaged (hole observed in stamping). If Yes, then the lot may be rejected at firm's works.	YES/NO
46	Whether Amorphous/CRGO are directly imported either from the manufacturer or through their accredited marketing organization of repute (and not through any agent).whether the copy of invoices of Amorphous/CRGO core material has been provided by the supplier at the time of inspection and same has been verified by the inspecting officer. If No, then the lot may be rejected at firm's works	YES/NO
47	Whether the Hexagonal head of antitheft fasteners are detached at M&P Box sliding cover. If No, then the lot may be rejected at firm's works.	YES/NO
48	Whether the Details of Make, Rating, Sr. No. And TN/Order No. Are punched or an identity plate with said details is welded on core coil assembly. If No, then the lot may be rejected at firm's works.	YES/NO
49	Whether Bi-metallic connectors on HV Bushing are provided as per specification. If No, then the lot may be rejected at firm's works	YES/NO
50	Whether Press Board used has been of senapathy whitely / Raman make/ Techno Electric, Hyderabad and Perma wood or haldu wood blocks has been used for Top and Bottom yoke insulation. If No, then the lot may be rejected at firm's works.	YES/NO
51	Whether dry type film thickness (DFT) of paint is as per specification. If No, then the lot may be rejected at firm's works.	YES/NO
52	Whether Oil level gauge of prismatic glass, indicating minimum position corresponds to operating temperature of 30 °C as per IS 1180 Part-1 : 2014 , has been provided above the Internal circuit breaker height. If No, then the lot may be rejected at firm's works.	YES/NO
53	Whether make of HV/LV Bushings is as per specification/PO. If No, then the lot may be rejected at firm's works.	YES/NO
54	Whether Technical cum Identification Plate of size 125 x 75 x 2.5 mm having details as per specification punched with letters of size 8mm X 6mm shall be continuously welded to the main tank body in clearly visible position. If No, then the lot may be rejected at firm's works.	YES/NO
55	Whether following mentioned are as per specification/approved drawing of M&P Box: i. size of PVC Copper cable ii. Size of lugs	YES/NO



	iii. make of Inbuilt circuit breaker If No, then the lot may be rejected at firm's works.	
56	Whether Provision shall be made for connecting the neutral HV terminal to local earth through a strip having width of 25 mm and 1 mm thickness. If No, then the lot may be rejected at firm's works.	YES/NO
57	Whether the circular bottom plate edges of the tank should be folded upward, for at least 25mm to have sufficient overlap with vertical sidewall of the transformer. If No, then the lot may be rejected at firm's works.	YES/NO
58	Whether the HV bushing pocket shall be embossed to topside of the top cover so as to eliminate ingress of moisture & water and the edges of the top cover shall be formed, so as to cover the top end of the tank and gasket. If No, then the lot may be rejected at firm's works.	YES/NO
59	Whether the creep age distance of HV& LV bushings are as per IS or not . If No, then the lot may be rejected at firm's works.	

**(Signature)**

Name & Designation  
with seal of the bidder

**Schedule – VI (A)**

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**  
**A Govt. of Rajasthan Undertaking**  
**DEPARTURE/DEVIATION FROM TECHNICAL SPECIFICATION**

The bidder shall state under this schedule the departure from the Purchaser's specification in respect of technical is as under:-

---

S.No.	Main Deviations from Technical Specification.
-------	---

---

---

Certified that we agree to all the technical specification of the NIT except for the deviation to the extent indicated above.

**(Signature)**  
Name & Designation  
with seal of the bidder.

**Schedule – VI (B)**

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**  
**A Govt. of Rajasthan Undertaking**  
**DEPARTURE FROM COMMERCIAL TERMS & CONDITIONS OF THE**  
**SPECIFICATION**

The bidder shall state under this schedule the departure from the Purchaser's specification in respect of Commercial terms & conditions:-

---

S.No.	Main Deviations from Specification.
-------	-------------------------------------

---

---

Certified that we agree to all the commercial terms & conditions as laid down in General Conditions of Contract to the specification except for the deviation to the extent indicated above.

**(Signature)**

Name & Designation  
with seal of the bidder.

**Schedule – VII****JODHPUR VIDYUT VITRAN NIGAM LIMITED****A Govt. of Rajasthan Undertaking  
LIST OF PAST SUPPLIES**

The bidder shall state under this schedule whether material and equipments, similar to those offered in the tender have been previously supplied by him. A list shall be given of such orders executed by him together with information regarding the names of purchasing organizations, quantities supplied and when the supplies were effected. This list should be in form given below:-

S.No.	Detailed particulars of items supplied	Qty in MT	Order No. & Date	Name & details of purchasing authority	Date of Completion
1	2	3	4	5	6

If executed partially to be mentioned in M.T.)	whether still to be executed	Delivery stipulated in order	Remarks (Qty.
7	8	9	10

**Note:** Separate schedules are to be furnished by the bidder for past supply to the JVVNL/AVVNL/JdVVNL, other State Electricity Boards and other Departments /Organisations.

**(Signature)**

Name & Designation  
with seal of the bidder.

**SCHEDULE-VIIA**  
**TN-1625**

**TO WHOMSOEVER IT MAY CONCERN**

This is to certify that M/s. \_\_\_\_\_ (Complete with address) have manufactured and supplied the goods / equipments / material during the following financial year(s) to the **Licensed Power Utilities / Government Departments / Discoms/ SEBs** as detailed out below:

**FOR THE LAST THREE FINANCIAL YEARS FROM THE DATE OF OPENING OF TECHNO-COMMERCIAL BID.**

S.No	Financial year in which material supplied	Detailed Particulars of item(s) supplied	Name and particulars of purchasing authority	Order No. & date against which item(s) supplied	Unit	Ordered		Actual supplied during the Financial Year		Remarks
						Quantity	Value (Rs)	Quantity	Value (Rs)	
1	2	3	4	5	6	7	8	9	10	11

Signature ,  
Name & Designation  
With Seal of the Bidder  
Date \_\_\_\_\_  
Place \_\_\_\_\_

Signature of C.A  
Name :  
Address:  
  
Membership No

The above particulars are true and correct based on explanations, records and books of accounts produced before us. Further the above certificate issued on the request of the company

CA Firm ( \_\_\_\_\_ )

**Note:- The C.A. certificate must be signed by the bidder and C.A. firm. The details i.e. address of C.A. & membership No. shall clearly be mentioned on C.A. certificate. In case C.A. certificate is not signed by the bidder/furnished without membership No. & address of C.A. then same may not be considered for which responsibility rests with the bidder.**

**SCHEDULE-VIII****JODHPUR VIDYUT VITRAN NIGAM LIMITED  
DELIVERY SCHEDULE AGAINST TN-1625****PART-A**

The delivery schedule of the material by the Purchase Officer is as mentioned hereunder:

<b>Sr. No.</b>	<b>Particulars of Material</b>	<b>Commencement period</b>	<b>Rate of supply per month of delivery of entire material</b>	<b>Period for completion of delivery material</b>
1.	11/√3 KV / 240 V, 5 <b>KVA</b> Rating Single Phase Aluminium Wound Energy Efficiency Level-2 Distribution Transformers with ICB	45 days from the date of receipt of P.O	_____ Nos. per month (to be quoted by tenderer)	Eight and half months excluding commencement period (Max.)

**PART-B**

In case tenderer deviates from the delivery schedule mentioned by the purchaser in Part-A then the delivery schedule by the tenderer shall be indicated/ mentioned as under:

<b>Sr. No.</b>	<b>Particulars of Material</b>	<b>Commencement period</b>	<b>Rate of supply per month of delivery of entire material</b>	<b>Period for completion of delivery material</b>
2.	11/√3 KV / 240 V, 5 KVA Rating Single Phase Aluminium Wound Energy Efficiency Level-2 Distribution Transformers with ICB			

**NOTE:**

- (i) **The offers deviating in deliveries mentioned above at part 'A' shall be considered as non responsive** in accordance to Clause No. 35 of the technical specification Section - III. **In case if ordered quantity is different than quoted quantity then monthly deliveries shall be adjusted proportionately.**
- (ii) During the commencement period the contractual formalities shall be got completed.

Signature  
Name & Designation  
With seal of the tenderer

**Schedule – IX**

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**

**A Govt. of Rajasthan Undertaking**

List of Equipments and Technical Hands Available with the Firm

(To be filled in by the bidders & enclosed with the bid)

Manufacturers and / or their authorized agents who are quoting against this bid are requested to furnish the following information along-with the bid. The Purchaser will have the discretion to ignore the bid without the under noted particulars and/or ignore the bid particulars.

1. Name and Address of Manufacturer.
2. Place where works exist.
3. Details of machinery particularly with B.H.P. of each item installed.
4. Details of staff employed in the works.
5. Date when started the manufacturing of item under reference.
6. List of items manufactured.
7. Literature and drawings of items manufactured showing their description, size, design and other important technical particulars.
8. Details of order so far, executed alongwith the names of organization to whom supplied.
9. Manufacturing capacity.
10. Is the workshop open for inspection by the representative of the board, if required?
11. Statement of financial resources and Banking Reference alongwith Balance-Sheet for previous two years.
12. Testing facilities available for the manufactured articles in the testing laboratory of works.
13. Whether the Firm is a small/medium/large scale industry.
14. Registration No. with :-
  - i. Small Scale, National/State.
  - ii. DGTD
  - iii. State Industries Department.

**(Signature)**

Name & Designation  
with seal of the bidder.

**Schedule – X**

**GENERAL PARTICULARS ABOUT THE TENDER IN BRIEF  
JODHPUR VIDYUT VITARAN NIGAM LIMITED  
MATERIAL MANAGEMENT CIRCLE**

**NEW POWER HOUSE, INDUSTRIAL AREA, JODHPUR-342003**

**Phone: (0291)2742223/Fax: (0291) 2746539/E-Mail:semmcjdvvn@gmail.com**

**SPECIFICATION FOR SUPPLY OF 11/√3 KV/240V, 5 KVA RATING OUT DOOR TYPE COMPLETELY SELF PROTECTED SINGLE PHASE ALUMINIUM WOUND DISTRIBUTION TRANSFORMERS ENERGY EFFICIENCY LEVEL-2 WITH INBUILT CIRCUIT BREAKER UNDER SPECIFICATION NO.JdVVNL/SE (MM&C)/EIAI/TN-1625.**

A	NIT No.	<b>TN-1625</b>
B	Cost of tender specifications	Rs. 2500.00 + GST@18% = Rs. 2,950.00 (Rs. Two Thousand Nine Hundred & Fifty Only)
C	Processing fee of RISL	Rs. 1000.00 (One Thousand Only)
D	Estimated Tender Value	<b>Rs. 32,21,00,000.00</b>
E	Bid Security to be deposited with the tender	(i) General Bidder: Rs. 64,42,000.00 (ii) Sick Unit : Rs. 32,21,000.00 (iii) SSI Units of Rajasthan : Rs. 16,10,500.00*
F	Validity	120 days from the next date of opening of techno-commercial bid.
G	Base date for price variation	<b>The base date will be 01.06.2020 irrespective of date of tender opening.</b>

**IMPORTANT DATES**

S.N	Events	Date & Time	Location
1	Date of downloading of tender specifications	Up to 30.07.2020 (06:00 PM)	<a href="http://www.jdvvn.com">www.jdvvn.com</a> & <a href="http://eproc.rajasthan.gov.in">http://eproc.rajasthan.gov.in</a>
2	Deposit of cost of Tender Specifications, Processing fee & Bid Security	Up to 30.07.2020 (4:00 PM)	Office of Sr. A.O (Cash & CPC), JdVVNL , New Power House, Industrial Area, Jodhpur
3	Last Date & time of submission of electronic bid	Up to 31.07.2020 (12:00 NOON)	<a href="http://eproc.rajasthan.gov.in">http://eproc.rajasthan.gov.in</a>
4	Opening of Technical Bid	31.07.2020 (3:00 PM)	<a href="http://eproc.rajasthan.gov.in">http://eproc.rajasthan.gov.in</a>
5	Opening of Price Bid	To be intimated separately to the qualified bidders	<a href="http://eproc.rajasthan.gov.in">http://eproc.rajasthan.gov.in</a>

**\*In case SSI unit of Rajasthan quotes the less than the tendered quantity , then they are required to furnish Bid security @ 0.5% of the estimated value of the quantity offered by them, failing which bid shall be considered non-responsive.**

The Micro, Small & Medium Scale Industries of Rajasthan and Sick Industries, other than Small Scale Industries, whose cases are pending before the Board of Industrial and Financial Reconstruction (BIFR) shall furnish self attested documentary evidence duly attested by notary to claim the above.

The bid security may be given in the form of banker's cheque or demand draft in favour of Senior Accounts Officer (Cash & CPC), JDVVNL, Jodhpur payable at Jodhpur or bank guarantee, in specified format, of a scheduled bank in favour of Superintending



Engineer (MM&C), JDVVNL, Jodhpur, be deposited to the Sr. Accounts Officer (MM&C), JDVVNL, Jodhpur up to stipulated date & time, and obtain a receipt/acknowledgement thereof. No other mode of deposit shall be accepted.

**At the time of depositing the Bid security amount in the office of the Sr. Accounts Officer (MM&C), JDVVNL, Jodhpur, the bidder shall also furnish self-attested documentary evidence duly attested by Notary of SSI unit of Rajasthan and of sick unit and also to submit a letter of quantity offered by them along with an Affidavit for MSME unit of Rajasthan in the enclosed format as per Schedule XI is to be furnished on non-judicial stamp paper of Rs.100/- duly attested by Notary public, to the office of Sr. Accounts Officer (MM&C), JDVVNL, Jodhpur. The Bid Security bank guarantee of requisite amount shall be furnished on non-judicial stamp paper of Rajasthan State. Also furnish the undertaking for the CA certificate in the enclosed format as per Annexure-I on non-judicial stamp paper of Rs.100/- duly attested by Notary public along with the original / notarised CA certificate as per requirement of tender specifications.**

**NOTE:-**

- 1. Wherever EMD and Security Bank Guarantee (SBG), are appearing in the ITB, GCC & other Bidding Documents, same is hereby replaced by BID SECURITY as above.**
- 2. VENDOR REGISTRATION: The relaxation/exemption given to the registered vendors of the Nigam in respect of EMD/SBG, wherever appearing in the ITB, GCC & other Bidding documents, are hereby WITHDRAWN.**

**VERY VERY IMPORTANT:**

1. The bids not accompanied with qualification requirement , technical requirement indicated in the specification and other requirement given here under will be considered as incomplete offer and sufficient grounds for offer to be passed over:

- i) Capacity, capability and competency proofing documents.
    - a) Capacity /orders of similar and higher rating of tendered equipment booked as on date of bidding with type and rating and construction details of equipment for which order received be indicated.
    - b) Copy of purchase orders of Erstwhile RSEB /SEB`S / Electric Utilities / Govt. Departments / Discom for similar or higher rating equipment latest executed.
  - ii) Year wise past experience for last 5 years of similar or higher rating of tendered equipment.
  - iii) The details of testing facilities available at the works and copies of latest type test certificates, carried out on similar ITEM.
  - iv) Quality assurance plan.
  - v) Complete guaranteed technical particulars, out lines and general arrangement drawings along with Bill of Material.
2. Bids without Section-I, II, III & Schedules (I to X) shall be rejected.
  3. Bids shall be furnished in single copy.

4. JDVVNL has the right to reject any offer on the basis of track record of poor performance in execution of previous order / equipment supplied /after sales service while evaluating the Techno-Commercial bid.
5. JDVVNL reserves the right to accept minor deviations in standard terms and conditions and also in technical and constructional features as specified in the technical specification **(Schedule-III)**.
6. Deviation of any kind shall not be quoted in price bid, if found quoted, the same shall be ignored.
7. The following facilities are to be provided by the supplier at his own cost to the inspecting officer of Nigam (JdVVNL).
  - i) Suitable accommodation.
  - ii) Local conveyance between arrival point, place of stay, works and departure point.
  - iii) The supplier shall assist in arranging return ticket and reservation on the request of the inspecting officer for which the payment shall be made by the inspecting officer. In case of joint inspection, single or shared double room accommodation shall be provided

-----

**Schedule – XI**

**Format of Affidavit for MSME  
(TO BE FURNISHED ON NON-JUDICIAL STAMP WORTH Rs.100/- & DULY  
NOTARIZED)**

I, \_\_\_\_\_ S/o \_\_\_\_\_ Aged \_\_\_ Years residing at  
\_\_\_\_\_ Proprietor/ Partner/ Director of M/s  
\_\_\_\_\_ do hereby solemnly affirm and declare  
that:-

- (a) My/ our above noted enterprise M/s \_\_\_\_\_ has been issued acknowledgement of Entrepreneurial Memorandum Part-II by the District Industries Center, \_\_\_\_\_. The acknowledgement No. is \_\_\_\_\_ dated \_\_\_\_\_ and has been issued for manufacture of following items:-
  - (i)
  - (ii)
  - (iii)
  - (iv)
- (b) My/ our above noted acknowledgement of Entrepreneurial Memorandum Part-II has not been cancelled or withdrawn by the Industries Department and that the enterprise is regularly manufacturing the above items.
- (c) My/our enterprise is having all the requisite plant and machinery and is fully equipped to manufacture the above noted items.
- (d) The present status of the firm is as per acknowledgment of Entrepreneurial Memorandum Part-II issued on the date of District Industries Center, \_\_\_\_\_.

Place  
Director/

Signature of Proprietor/

Authorized Signatory with Stamp and Date

**VERIFICATION**

I, \_\_\_\_\_ S/o \_\_\_\_\_ Aged \_\_\_ Years residing at  
\_\_\_\_\_ Proprietor/ Partner/ Director of M/s  
\_\_\_\_\_ verify and confirm that the contents at  
(a), (b), (c) & (d) above are true and correct to the best of my knowledge and nothing  
has been concealed therein. So, help me God.

**DEPONENT**

**Annexure 'A'**

**(SELF ATTESTED UNDERTAKING TO BE GIVEN ON FIRM'S LETTER HEAD)**

In relation to my/ our bid submitted to SE (MM&C) For procurement of \_\_\_\_\_ in response to their notice inviting bids under TN- \_\_\_\_ I/We hereby declare under section 7 of Rajasthan Transparency in Public Procurement Act, 2012, that : -

1. Our firm, its affiliates of subsidiaries including any subcontractor or suppliers for any part of the contract have not debarred by the state government or the procuring entity or a regulatory authority under any applicable law.
2. We declare that we have complied with and shall continue to comply with the provision of the code of integrity including conflict of interest as specified for bidders in the RTPP Act 2012, RTPP Rules 2013 and the bidding document during the procurement process and execution of contract till completion of all our obligation under contract.
3. I/We possess the necessary professional, technical, financial and managerial resources and competence required by the bidding document issued by the procuring entity.
4. I/We have fulfilled my/ our obligation to pay such of the taxes payable to the Union and the State Government or any local authority as specified in the bidding document.
5. I/We are not insolvent, in receivership, bankrupt or being wound up, not have my/ our affairs administered by a court or a judicial officer, not have my/ our business activities suspended and not the subject of legal proceeding for any of the foregoing reasons.
6. I/We do not have, and our directors and officers not have, been convicted of any criminal offence related to my/ our professional conduct or the making of false statements or misrepresentations as to my/ our qualifications to enter into a procurement contract within a period of three years preceding the commencement of this procurement process, or not have been otherwise disqualified pursuant to debarment proceedings.
7. I/We do not have a conflict of interest as specified in the Act, Rules and the bidding document, which materially affects fair competition.

Date :  
Place :

Siganture of bidder  
Name :  
Designation :  
Address :

**Annexure-I**

**UNDERTAKING FOR CA CERTIFICATE**

**(TO BE FURNISHED ON NON-JUDICIAL STAMP WORTH Rs.100/- & DULY NOTARIZED)**

I/WE UNDERTAKE THAT THE CA CERTIFICATE SUBMITTED AS PER THE REQUIREMENT OF PRE-QUALIFICATION REQUIREMENTS, FOR ADJUDGING THE PAST SUPPLIES ,UNDER THE SUBJECT TENDER, **TN-1625**, IS CORRECT AND I, UNDERSIGNED WILL BE SOLELY RESPONSIBLE FOR ANY DEVAITION/DISCREPANCY/IN-CORRECT INFORMATION , IF EVER NOTICED IN THE CA CERTIFICATE.

FURHER, IN CASE, IF ANY DEVAITION/DISCREPANCY/IN-CORRECT INFORMATION IS NOTICED IN THE CA CERTIFICATE FURNISHED WITH THE BID, AT ANY STAGE DURING PROCESSING/ CURRENCY OF TENDER, DISCOM CAN TAKE THE ACTION

AGAINST THE FIRM  
M/s \_\_\_\_\_ AS

PER THE RULES & REGULATIONS.

**(SIGNATURE)**

NAME & DESIGNATION  
WITH SEAL OF THE BIDDER.

**APPENDIX-A****Bank Guarantee No.** \_\_\_\_\_.

Security Amount : \_\_\_\_\_.

Issued on dated : \_\_\_\_\_.

Valid upto : \_\_\_\_\_.

Claim upto / Grace period: \_\_\_\_\_.

**PERFORMA OF BANK GUARANTEE FOR BID SECURITY**

(Bank Guarantee in lieu of bid Security on non-judicial Stamp Paper of Rajasthan State of 0.25% of the B.G. value or Rs.25,000/-, whichever is less)

To,

The Superintending Engineer (MM&C),  
Jodhpur Vidyut Vitaran Nigam Limited,  
Jodhpur.

1. Whereas \_\_\_\_\_ (name of the Bidder) (hereinafter called "the Bidder") has submitted its bid dated \_\_\_\_ (date of submission of bid) for \_\_\_\_\_ (name of contract/ name of the material with Bid no. / TN No. \_\_\_\_\_) (hereinafter called "the Bid").
2. KNOW ALL PEOPLE by these presents that WE \_\_\_\_\_ (name and address of branch of Bank ) of \_\_\_\_\_ (name of country), having our registered office at \_\_\_\_\_ (addresses of bank) (hereinafter called "the Bank"), are bound unto \_\_\_\_\_ (name of Purchaser) (hereinafter called "the Purchaser") in the sum of Rs. \*\_\_\_\_\_ for which payment well and truly to be made to the said Purchaser, the Bank binds itself, its successors, and assigns by these presents sealed with the Common Seal of the said Bank this \_\_\_\_\_ day of \_\_\_\_\_ 20\_\_\_\_.
3. THE CONDITIONS of this obligation are :
  - i. If the bidder withdraws its Bid during the period of bid validity specified by the Bidder in the Bid Form; or
  - ii. If the bidder refuses to accept the correction of error in his Bid; or
  - iii. If the bidder, having been notified of the acceptance of its Bid by the purchaser during the period of bid validity:
    - a. Fails or refuses to execute the Contract Agreement within the time specified in purchase / work order, if required, or
    - b. Fails or refuses to furnish the performance security within the time specified in purchase / work order in accordance with the GCC, or
    - c. Fails to commence supply of goods or services or execute work as per purchase / work order within time specified.
  - iv. If the bidder breaches any provision of the Code of integrity specified in the RTPP Act and Chapter VI of the RTPP Rules.
4. We undertake unconditionally and irrevocably to guarantee as primary obligator and not as surety merely to pay to the purchaser a sum of Rs. \_\_\_\_\_ (in words Rs. \_\_\_\_\_) upon receipt of its first written demand, without the purchaser having to substantiate its demand, provided that in its demand the Purchaser will note that the amount claimed by it is due to it owing to the occurrence of one or all of the three conditions specifying the occurred condition or conditions.

5. The decision of the Superintending Engineer (MM&C), Jodhpur Vidyut Vitaran Nigam Limited, Jodhpur shall be final whether breach has been committed on the right to demand the amount of guarantee from us which has accrued to the purchaser.
6. This guarantee shall not cease or determine, if the purchaser grants time or indulgence or vary the terms of the contract with the Contractor or without our consent or knowledge.
7. The guarantee herein contained shall not be affected by any change in the constitution of the Contractor.
8. We \_\_\_\_\_ (Bank Name) further undertake not to revoke this guarantee during its currency except with the previous consent of the Superintending Engineer (MM&C), Jodhpur Vidyut Vitaran Nigam Limited, Jodhpur.
9. All disputes arising under the said guarantee between the Bank and the Nigam or between the Contractor and the Nigam pertaining to the guarantee, shall be subject to the jurisdiction of the Courts in Jodhpur, Rajasthan alone.
10. This guarantee will remain in force up to and including one hundred eighty (180) days after the date of the opening of bids, i.e. upto \_\_\_\_\_, with a further grace period of Ninety (90) days and any demand in respect thereof should reach the Bank not later than the above date.

Yours faithfully,  
Bankers (EXECUTANT)

Signed by the above named Bank in presence of :  
(signature with full Name and Address)

Witness :

1. \_\_\_\_\_.
2. \_\_\_\_\_.

Attested by Notary Public, First Class Magistrate or directly confirmed by the executing Bank.

\* The Bidder should insert the amount of the guarantee in words and figures denominated in the currency of bid.

**Note :** In case the bid is submitted by a Joint Venture, the Bid Bank guarantee shall be in the name of Lead partner or in the name of joint venture partners submitting the Bid covering all the partners of the joint vent

**AMENDMENT IN ITB AND GCC**

- 1) **Wherever EMD and Security Bank Guarantee (SBG), are appearing in the ITB, GCC & other Bidding Documents, same is hereby replaced by BID SECURITY as under:-**

**BID SECURITY**

Bid security shall be 2% **of the estimated value of subject matter of procurement put to bid.** In case of Small Scale Industries of Rajasthan it shall be 0.5% of the **quantity offered** for supply and in case of sick industries, other than Small Scale Industries, whose cases are pending with Board of Industrial and Financial Reconstruction, it shall be 1% of the value of bid. Every bidder, if not exempted, participating in the procurement process shall be required to furnish the bid security as specified in the notice inviting bids.

**In case SSI unit of Rajasthan quotes the less than the tendered quantity, then they are required to furnish Bid Security @ 0.5% of the estimated value of the quantity offered by them, failing which bid shall be considered non-responsive.**

The Bid Security amount (as applicable) to be paid by Demand Draft/Banker's Cheque in favour of SR. AO (CASH & CPC), JDVVNL, Jodhpur (payable at Jodhpur) **upto 4.00 p.m. upto one WORKING day prior to schedule date of opening** of respective bid or Bank Guarantee, in specified format, of a scheduled bank in favour of The Superintending Engineer (MM&C), JDVVNL, Jodhpur, be deposited to the Sr. Accounts Officer (MM&C), JDVVNL, New Power House, Industrial Area, Jodhpur-342003 **upto 4.00 p.m. upto one WORKING day prior to schedule date of opening** of respective bid **and obtain a receipt / acknowledgement thereof. No other mode of deposit shall be accepted. At time of depositing the Bid Security amount or Bank Guarantee, the bidder shall also furnish self attested and duly attested by Notary the documentary evidence of SSI unit of Rajasthan or of sick unit (as applicable) and also submit a letter for the offered quantity by them alongwith an Affidavit for MSME unit of Rajasthan in the enclosed format as per Schedule XI is to be furnished on non-judicial stamp paper of Rs.100/- duly attested by Notary public, to the office of Sr. Accounts Officer (MM&C), JDVVNL, Jodhpur. The Bid Security bank guarantee of requisite amount shall be furnished on non-judicial stamp paper of Rajasthan State. Also furnish the undertaking for the CA certificate in the enclosed format as per **Annexure-I** on non-judicial stamp paper of Rs.100/- duly attested by Notary public alongwith the original / notarised CA certificate as per requirement of tender specifications. Further, declaration for RTPP duly self attested on letter head as per the Annexure-A shall also be furnished as per requirement of tender specifications.**

The Bank Guarantee against Bid Security be issued by Nationalized / Scheduled Bank. The same may be accepted after confirmation by issuing Bank. If any Bid Security Bank Guarantee not is proper format / not confirmed by the issuing Bank the same would not be accepted and the bidder would be immediately shorted out from bid process.

The Micro, Small & Medium Scale Industries of Rajasthan and sick industries, other than Small Scale Industries, whose cases are pending before the Board of Industrial and Financial Reconstruction (BIFR) shall furnish self-attested documentary evidence duly attested by Notary to claim the above.



**2) Wherever Performance Bank Guarantee (PBG) and Composite Bank Guarantee (CBG) are appearing in the ITB, GCC & other Bidding Documents, same are hereby replaced by PERFORMANCE SECURITY as under:-**

**PERFORMANCE SECURITY:**

- (i) Performance security shall be solicited from all successful bidders except the department's of the State Government and undertakings, corporations, autonomous bodies, registered societies, co-operative societies which are owned or controlled or managed by the State Government and undertakings of the Central Government. However, a performance security declaration shall be taken from them. The State Government may relax the provision of performance security in particular procurement or any class of procurement.
- (ii) The amount of performance security shall be **five percent** of the amount of supply order in case of procurement of goods and services and **ten percent** of the amount of work order in case of procurement of works **In case of Micro, Small and Medium Scale Industries of Rajasthan** it shall be **one percent** of the amount of quantity ordered for supply of goods and in case of sick industries, other than Small Scale Industries, whose cases are pending before the Board of Industrial and Financial Reconstruction (BIFR), it shall be **two percent** of the amount of supply order.

**3) VENDOR REGISTRATION**

The **relaxation/exemption given to the registered vendors of the Nigam in respect of EMD/SBG, wherever appearing in the ITB, GCC & other Bidding documents, are hereby WITHDRAWN.**

- 4) The indirect taxes i.e. Excise Duty, Service Tax, VAT/CST, Entry Tax etc. mentioned in G.C.C., may now be read as G.S.T.**
- 5) G.S.T. will be charged extra at the prevailing rate on all the Settlement Fees as applicable and amended time to time.**
- 6) The Clause No. 1.43 of GCC has been amended to the extent as under:**

**1.43 DUE DATE OF PAYMENT:**

Payment shall be due and payable by the purchaser in accordance with the provision of the contract within a reasonable period from the date of receipt of each invoice by the contractor / supplier duly supported by a certificate of the Engineer. The purchaser will take all possible effort to make payment to the contractor / supplier generally on **45<sup>th</sup> day** after receipt of duly verified challans / receipts / bill in the office of paying authority (Sr. Accounts Officer (Cash & CPC) Jodhpur Discom, Jodhpur / Concerned Circle Accounts Officer) and completion of contractual formalities. But in case of delay in payment the purchaser shall not be liable to pay any interest on the outstanding amount to the contractor / supplier.

- 7) In case the terms & conditions mentioned in the PO, ITB & GCC are modified/differ from RTPP Act, then RTPP Act shall supersede.**

## **ADDENDUM IN ITB**

**Addendum in the provision of Instruction to Bidder (ITB) in the clause No. 1.12.2 for quantity allocation as per award criteria of purchase manual in accordance to the clause no. 74 of RTPP rules:**

### **1.12.2 (A) for quantity allocation**

#### **(i) Trial order under Para No. 22.17 (a) & (b) of purchase manual**

(a) Any bidder located within or outside the state of Rajasthan has participated for the first time in a particular Discom& meeting minimum qualification requirement and has supplied the tendered material/or of higher rating in other utility shall be treated as an old supplier. Rajasthan's firms although supplied in past but not meeting minimum quantity supplied criterion including altogether new units which have not supplied any quantity but having adequate & required manufacturing and testing facility and technical know-how of the tendered material shall be considered as new firms and would be eligible for trial order only. In case supply made to the licensed power utility outside India, the C.A. certificate furnished by the firm shall be considered.

Note:- The material supplied and accepted for same/higher rating for turnkey project (s) to a licensed power utility/Govt. shall be considered for the purpose of evaluating criteria. The certificate given by C.A. shall indicate above quantity separately.

(b) (i) The trial order for a particular item shall not generally exceed 10% of the total quantity considered for placement of order. This ceiling may, however, be relaxed by the corporate level purchase committee up to the extent of 30% to take the advantage of lower price where situation of differential price offering is arising.

(ii) The capacity & capability assessment of a bidder located outside state of Rajasthan who otherwise qualifies but is participating for the first time shall not be carried out.

Similarly, for the tendered item(s) where the valid BIS license is an essential qualification requirement and the bidder possesses the valid BIS but new to the utility. The capacity/capability assessment of such a bidder shall also not be carried out.

#### **(ii) Award criteria under Para No. 10.2 (iii) of purchase manual**

(a) In case of distribution transformers of rating 40 KVA and below, LT cables & conductors and fabricated steel items, order quantity may be distributed in the following manner:-

**20% to L1**

**15% to L2**

**10% to L3**

**05% to L4**

50% to be distributed equally among other firms subject to the condition that not more than 5% of the quantity to be purchased will be allotted to any one of such firms. The balance, if any will be distributed in the same proportion as indicated above among the first four firms.

(b) In case of other items except poles, order quantity may be distributed in the following manner:-

**40% to L1**

**20% to L2**

**10% to L3**

**06% to L4**

The balance quantity may be equally distributed among other firms subject to the condition that not more than 4% of the quantity to be purchased will be allotted to any one of such firm. The balance, if any will be distributed in the same proportion as indicated above among the first four firms.

(c) In case of poles, the order may be awarded on the basis of landed cost (material and transportation taken together). The allocation of quantity location/destination wise may be made among the eligible firms in equal proportion as far as possible