



# RAJASTHAN RAJYA VIDYUT UTPADAN NIGAM LIMITED

Corporate Identity Number (CIN)- U40102RJ2000SGC016484  
Regd. Office & H. O.: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302005

## DHOLPUR COMBINED CYCLE POWER PROJECT

Near Purani Chhawani, Dholpur (Rajasthan)-328 001



**R.K.Verma**

Superintending Engineer (Proc.)

Mobile No. 9413384564

**E-MailID:** [se2.dccpp@rrvunl.com](mailto:se2.dccpp@rrvunl.com),

[dccppprocurement@rediffmail.com](mailto:dccppprocurement@rediffmail.com)

**No.:** - RRVUNL | DCCPP | CE | SE (Proc.) | XEn (Proc.) | F.1043 | D.

**Dated:**

### CORRIGENDUM-1

Technical Specification and A-2 Schedule of tender document for **“Supply, installation, testing & commissioning of Aviation Obstacle LED Light at DCCPP, Dholpur”** is hereby corrected (as per Annexure enclosed) to be read as under: -

#### 1. Technical specification -

Sr. No.	Type of Light	Qty. required	Place to install
1.	Medium Intensity Lights (Type B) with all required fitting accessories, wire , cable, fixture etc.	06 Nos.	At the top of main stack, there are two stakes are available at DCCPP, Dholpur and Height of each stake is around 70 mtrs. 03 Nos. of medium intensity light have to be installed at the top of main stake.
2.	Low Intensity Lights (Type B) with all required fitting accessories, wire , cable, fixture etc.	10 No.	At the mid of each main stack and at the top of each bypass stack (2Nos. by pass stake having height of 35 mtr. Approx. are available at DCCPP, Dholpur).
3.	Master Controller with all required fitting accessories, wire , cable, fixture etc.	2 Nos.	For each stake to control aviation lights.
4.	All external wiring and ETC work has to be done by bidder by using 3- core copper armor cables.		
5.	As per design and drawing, all associated accessories like Power distribution panel, communication junction box, cable, etc. will be on bidder's scope.		
6.	The participating bidders are advised to take prior approval of design & drawing of all light and associated accessories.		
7.	The design and drawing shall be prepared and furnish by the bidder, no any drawing will be provided by DCCPP, Dholpur as first time installation. The bidders are advised to visit site before bidding.		

#### 2. A-2 Schedule (point No. 25)- Part order not applicable .

All other technical specification alongwith terms & conditions of the tender documents will remain unchanged.

Superintending Engineer (Proc.)  
DCCPP, RRVUNL, Dholpur

